



**Bid  
26-21**

**for**

## **Leahy Park Fieldhouse Renovation**

**ADDENDUM No. 3**

**April 7, 2026**

Any and all changes to the Bid are valid only if they are included by written addendum to all potential respondents, which will be emailed prior to the proposal due date. Each respondent must acknowledge receipt of any addenda by indicating in its proposal. Each respondent, by acknowledging receipt of addenda, is responsible for the contents of the addenda and any changes to the bid therein. Failure to acknowledge receipt of addenda may cause the submittal to be rejected. If any language or figures contained in this addendum are in conflict with the original document, this addendum shall prevail.

This addendum consists of the following:

1. Addendum No. 3 is attached and consists of a total of two (2) pages, including this cover sheet.

Please contact me at 847-866-2935 [tnunez@cityofevanston.org](mailto:tnunez@cityofevanston.org) with any further questions or comments.

Sincerely,

Tammi Nunez  
Purchasing Manager

**Bid 26-21**

**For**

**Leahy Park Fieldhouse Renovation**

**ADDENDUM No. 3**

**April 7, 2026**

This addendum forms part of the Bid Documents for Bid #26-21 and modifies them. This addendum consists of the following:

Q. With the bathroom wall being relocated ~12" to the east, will anything need to be done to the existing concrete slab at the new wall location?

A. Provide pressure-treated sill plates over concrete slab with continuous closed-cell sill sealer. Provide continuous bead of sealant at plate perimeter. Anchor plates to slab with 1/2" diameter wedge anchors at 6'-0" o.c. maximum and within 12" of plate ends. Provide anchors at each side of openings. Minimum embedment 3". Provide approved post bases at all posts, anchored to slab per manufacturer requirements.

Existing concrete slab-on-grade is assumed to be adequate to support new interior wall loads. No slab thickening or continuous footing is anticipated. Contractor shall notify Architect if field conditions indicate otherwise.

**Note: Acknowledgment of this Addendum is required in the Submittal.**