

Historical PFAS Results

The United States Environmental Protection Agency published its first ever National Primary Drinking Water Regulation (NPDWR) for PFAS on April 26, 2024. The Illinois Environmental Protection Agency (IEPA) expects to adopt this regulation by April 2025. This regulation established Maximum Contaminant Levels (MCLs) for six PFAS in drinking water. MCLs are the highest allowable level of chemicals in drinking water. If the chemical is found at levels above the MCLs, EPA requires water utilities to treat the water. The City of Evanston's drinking water meets these new PFAS drinking water standards. The MCLs are PFOA: 4.0 parts per trillion (ppt), PFOS: 4.0 ppt, Perfluorohexane sulfonic acid (PFHxS): 10 ppt, Perfluorononanoic acid (PFNA): 10 ppt, GenX: 10 ppt. Hazard Index for mixture of PFHxS, PFNA, GenX, and perfluorobutane sulfonic acid (PFBS): 1. The IEPA has a limit of 3500 ppt for Perfluorohexanoic acid (PFHxA). Communities along the west shore of Lake Michigan are seeing similar results at about 2 ppt on average.

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3

4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/8/2026	Perfluorooctane sulfonate (PFOS)	1.7	1.6
1/8/2026	Perfluorooctanoic acid (PFOA)	1.7	1.7
1/8/2026	Perfluoroundecanoic acid (PFUnA)	<0.4	<0.4
1/8/2026	Perfluorohexanoic acid (PFHxA)	1.2	1.3
1/8/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
1/8/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.4
1/8/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.5
1/8/2026	Perfluorobutanesulfonic acid (PFBS)	<0.4	<0.4
1/8/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
1/8/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
1/8/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.7
1/8/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
1/8/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
1/8/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.6
1/8/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.4
1/8/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.4
1/8/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
1/8/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
1/8/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.06
10/9/2025	Perfluorooctane sulfonate (PFOS)	1.8	2

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/9/2025	Perfluorooctanoic acid (PFOA)	1.8	1.7
10/9/2025	Perfluoroundecanoic acid (PFUnA)	<0.4	<0.4
10/9/2025	Perfluorohexanoic acid (PFHxA)	1.2	1.2
10/9/2025	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
10/9/2025	Perfluorodecanoic acid (PFDA)	<0.4	<0.4

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/9/2025	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
10/9/2025	Perfluorobutanesulfonic acid (PFBS)	<0.4	<0.4
10/9/2025	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
10/9/2025	Perfluorononanoic acid (PFNA)	<0.5	<0.5
10/9/2025	Perfluorotetradecanoic acid (PFTeDA)	<0.7	<0.7

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/9/2025	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
10/9/2025	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
10/9/2025	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.6	<0.6
10/9/2025	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)(GenX)	<0.4	<0.4
10/9/2025	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.4	<0.4

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/9/2025	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
10/9/2025	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
10/9/2025	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.06
7/7/2025	Perfluorooctane sulfonate (PFOS)	1.8	1.8

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/7/2025	Perfluorooctanoic acid (PFOA)	1.8	1.8
7/7/2025	Perfluoroundecanoic acid (PFUnA)	<0.6	<0.6
7/7/2025	Perfluorohexanoic acid (PFHxA)	1.2	1.2
7/7/2025	Perfluorododecanoic acid (PFDoA)	<0.7	<0.7
7/7/2025	Perfluorodecanoic acid (PFDA)	<0.5	<0.5

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/7/2025	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
7/7/2025	Perfluorobutanesulfonic acid (PFBS)	<0.6	<0.6
7/7/2025	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
7/7/2025	Perfluorononanoic acid (PFNA)	<0.5	<0.5
7/7/2025	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/7/2025	Perfluorotridecanoic acid (PFTrDA)	<0.6	<0.6
7/7/2025	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.5	<0.5
7/7/2025	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.6	<0.6
7/7/2025	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)(GenX)	<0.7	<0.7
7/7/2025	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.5	<0.5

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/7/2025	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.6	<0.6
7/7/2025	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.5	<0.5
7/7/2025	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
4/10/2025	Perfluorooctane sulfonate (PFOS)	1.8	1.8

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/10/2025	Perfluorooctanoic acid (PFOA)	2	1.9
4/10/2025	Perfluoroundecanoic acid (PFUnA)	<0.6	<0.6
4/10/2025	Perfluorohexanoic acid (PFHxA)	1.3	1.3
4/10/2025	Perfluorododecanoic acid (PFDoA)	<0.7	<0.7
4/10/2025	Perfluorodecanoic acid (PFDA)	<0.5	<0.5

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/10/2025	Perfluorohexanesulfonic acid (PFHxS)	0.8	0.7
4/10/2025	Perfluorobutanesulfonic acid (PFBS)	<0.6	<0.6
4/10/2025	Perfluoroheptanoic acid (PFHpA)	1.1	1
4/10/2025	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/10/2025	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/10/2025	Perfluorotridecanoic acid (PFTrDA)	<0.6	<0.6
4/10/2025	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.5	<0.5
4/10/2025	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.6	<0.6
4/10/2025	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)(GenX)	<0.7	<0.7
4/10/2025	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.5	<0.5

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/10/2025	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.6	<0.6
4/10/2025	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.5	<0.5
4/10/2025	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.09	0.08
2/6/2025	Perfluorooctane sulfonate (PFOS)	2	<0.6

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
2/6/2025	Perfluorooctanoic acid (PFOA)	2.3	<0.6
2/6/2025	Perfluoroundecanoic acid (PFUnA)	<0.7	<0.7
2/6/2025	Perfluorohexanoic acid (PFHxA)	1.3	<0.5
2/6/2025	Perfluorododecanoic acid (PFDoA)	<0.8	<0.8
2/6/2025	Perfluorodecanoic acid (PFDA)	<0.6	<0.6

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
2/6/2025	Perfluorohexanesulfonic acid (PFHxS)	0.7	<0.6
2/6/2025	Perfluorobutanesulfonic acid (PFBS)	<0.6	<0.6
2/6/2025	Perfluoroheptanoic acid (PFHpA)	1	<0.6
2/6/2025	Perfluorononanoic acid (PFNA)	<0.5	<0.6
2/6/2025	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.7

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
2/6/2025	Perfluorotridecanoic acid (PFTrDA)	<0.6	<0.7
2/6/2025	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.5	<0.5
2/6/2025	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.6	<0.6
2/6/2025	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)(GenX)	<0.7	<0.8
2/6/2025	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.5	<0.6

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
2/6/2025	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.6	<0.6
2/6/2025	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.5	<0.6
2/6/2025	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.08	
10/24/2024	Perfluorooctane sulfonate (PFOS)	1.7	1.6

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/24/2024	Perfluorooctanoic acid (PFOA)	1.7	1.6
10/24/2024	Perfluoroundecanoic acid (PFUnA)	<0.5	<0.5
10/24/2024	Perfluorohexanoic acid (PFHxA)	1.3	1.2
10/24/2024	Perfluorododecanoic acid (PFDoA)	<0.5	<0.5
10/24/2024	Perfluorodecanoic acid (PFDA)	<0.5	<0.5

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/24/2024	Perfluorohexanesulfonic acid (PFHxS)	0.7	0.7
10/24/2024	Perfluorobutanesulfonic acid (PFBS)	<0.5	<0.5
10/24/2024	Perfluoroheptanoic acid (PFHpA)	1	0.9
10/24/2024	Perfluorononanoic acid (PFNA)	<0.5	<0.5
10/24/2024	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/24/2024	Perfluorotridecanoic acid (PFTrDA)	<0.6	<0.6
10/24/2024	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
10/24/2024	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
10/24/2024	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<0.7	<0.7
10/24/2024	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.5	<0.5

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/24/2024	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.5	<0.5
10/24/2024	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.5	<0.5
10/24/2024	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07778	0.07778
8/1/2024	Perfluorooctane sulfonate (PFOS)	2	1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
8/1/2024	Perfluorooctanoic acid (PFOA)	1.9	2.1
8/1/2024	Perfluoroundecanoic acid (PFUnA)	<0.6	<0.6
8/1/2024	Perfluorohexanoic acid (PFHxA)	1.2	1.2
8/1/2024	Perfluorododecanoic acid (PFDoA)	<0.7	<0.7
8/1/2024	Perfluorodecanoic acid (PFDA)	<0.5	<0.5

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
8/1/2024	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
8/1/2024	Perfluorobutanesulfonic acid (PFBS)	<0.6	<0.6
8/1/2024	Perfluoroheptanoic acid (PFHpA)	0.9	0.8
8/1/2024	Perfluorononanoic acid (PFNA)	<0.5	<0.5
8/1/2024	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
8/1/2024	Perfluorotridecanoic acid (PFTrDA)	<0.6	<0.6
8/1/2024	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.5	<0.5
8/1/2024	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.6	<0.6
8/1/2024	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<0.7	<0.7
8/1/2024	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.5	<0.5

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
8/1/2024	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.6	<0.6
8/1/2024	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.5	<0.5
8/1/2024	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
4/10/2024	Perfluorooctane sulfonate (PFOS)	<2.0	<2.0

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/10/2024	Perfluorooctanoic acid (PFOA)	<2.0	2
4/10/2024	Perfluoroundecanoic acid (PFUnA)	<2.0	<2.0
4/10/2024	Perfluorohexanoic acid (PFHxA)	<2.0	<2.0
4/10/2024	Perfluorododecanoic acid (PFDoA)	<2.0	<2.0
4/10/2024	Perfluorodecanoic acid (PFDA)	<2.0	<2.0

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/10/2024	Perfluorohexanesulfonic acid (PFHxS)	<2.0	<2.0
4/10/2024	Perfluorobutanesulfonic acid (PFBS)	<2.0	<2.0
4/10/2024	Perfluoroheptanoic acid (PFHpA)	<2.0	<2.0
4/10/2024	Perfluorononanoic acid (PFNA)	<2.0	<2.0
4/10/2024	Perfluorotetradecanoic acid (PFTeDA)	<2.0	<2.0

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/10/2024	Perfluorotridecanoic acid (PFTrDA)	<2.0	<2.0
4/10/2024	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<2.0	<2.0
4/10/2024	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<2.0	<2.0
4/10/2024	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<2.0	<2.0
4/10/2024	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<2.0	<2.0

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/10/2024	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<2.0	<2.0
4/10/2024	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<2.0	<2.0
1/23/2024	Perfluorooctane sulfonate (PFOS)	<1.9	2
1/23/2024	Perfluorooctanoic acid (PFOA)	2.1	2.1

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/23/2024	Perfluoroundecanoic acid (PFUnA)	<1.9	<1.9
1/23/2024	Perfluorohexanoic acid (PFHxA)	<1.9	<1.9
1/23/2024	Perfluorododecanoic acid (PFDoA)	<1.9	<1.9
1/23/2024	Perfluorodecanoic acid (PFDA)	<1.9	<1.9
1/23/2024	Perfluorohexanesulfonic acid (PFHxS)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/23/2024	Perfluorobutanesulfonic acid (PFBS)	<1.9	<1.9
1/23/2024	Perfluoroheptanoic acid (PFHpA)	<1.9	<1.9
1/23/2024	Perfluorononanoic acid (PFNA)	<1.9	<1.9
1/23/2024	Perfluorotetradecanoic acid (PFTeDA)	<1.9	<1.9
1/23/2024	Perfluorotridecanoic acid (PFTrDA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/23/2024	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<1.9	<1.9
1/23/2024	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<1.9	<1.9
1/23/2024	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9	<1.9
1/23/2024	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<1.9	<1.9
1/23/2024	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/23/2024	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9	<1.9
10/4/2023	Perfluorooctane sulfonate (PFOS)	2.2	2.3
10/4/2023	Perfluorooctanoic acid (PFOA)	2.9	3.1
10/4/2023	Perfluoroundecanoic acid (PFUnA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/4/2023	Perfluorohexanoic acid (PFHxA)	<1.9	<1.9
10/4/2023	Perfluorododecanoic acid (PFDoA)	<1.9	<1.9
10/4/2023	Perfluorodecanoic acid (PFDA)	<1.9	<1.9
10/4/2023	Perfluorohexanesulfonic acid (PFHxS)	<1.9	<1.9
10/4/2023	Perfluorobutanesulfonic acid (PFBS)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/4/2023	Perfluoroheptanoic acid (PFHpA)	<1.9	<1.9
10/4/2023	Perfluorononanoic acid (PFNA)	<1.9	<1.9
10/4/2023	Perfluorotetradecanoic acid (PFTeDA)	<1.9	<1.9
10/4/2023	Perfluorotridecanoic acid (PFTrDA)	<1.9	<1.9
10/4/2023	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/4/2023	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<1.9	<1.9
10/4/2023	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9	<1.9
10/4/2023	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<1.9	<1.9
10/4/2023	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/4/2023	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9	<1.9
7/5/2023	Perfluorooctane sulfonate (PFOS)	2.4	2.3
7/5/2023	Perfluorooctanoic acid (PFOA)	2.5	2.3
7/5/2023	Perfluoroundecanoic acid (PFUnA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/5/2023	Perfluorohexanoic acid (PFHxA)	<1.9	<1.9
7/5/2023	Perfluorododecanoic acid (PFDoA)	<1.9	<1.9
7/5/2023	Perfluorodecanoic acid (PFDA)	<1.9	<1.9
7/5/2023	Perfluorohexanesulfonic acid (PFHxS)	<1.9	<1.9
7/5/2023	Perfluorobutanesulfonic acid (PFBS)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/5/2023	Perfluoroheptanoic acid (PFHpA)	<1.9	<1.9
7/5/2023	Perfluorononanoic acid (PFNA)	<1.9	<1.9
7/5/2023	Perfluorotetradecanoic acid (PFTeDA)	<1.9	<1.9
7/5/2023	Perfluorotridecanoic acid (PFTrDA)	<1.9	<1.9
7/5/2023	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/5/2023	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<1.9	<1.9
7/5/2023	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9	<1.9
7/5/2023	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<1.9	<1.9
7/5/2023	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/5/2023	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9	<1.9
4/6/2023	Perfluorooctane sulfonate (PFOS)	2.4	2.3
4/6/2023	Perfluorooctanoic acid (PFOA)	2.4	2.3
4/6/2023	Perfluoroundecanoic acid (PFUnA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/6/2023	Perfluorohexanoic acid (PFHxA)	<1.9	<1.9
4/6/2023	Perfluorododecanoic acid (PFDoA)	<1.9	<1.9
4/6/2023	Perfluorodecanoic acid (PFDA)	<1.9	<1.9
4/6/2023	Perfluorohexanesulfonic acid (PFHxS)	<1.9	<1.9
4/6/2023	Perfluorobutanesulfonic acid (PFBS)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/6/2023	Perfluoroheptanoic acid (PFHpA)	<1.9	<1.9
4/6/2023	Perfluorononanoic acid (PFNA)	<1.9	<1.9
4/6/2023	Perfluorotetradecanoic acid (PFTeDA)	<1.9	<1.9
4/6/2023	Perfluorotridecanoic acid (PFTrDA)	<1.9	<1.9
4/6/2023	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/6/2023	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<1.9	<1.9
4/6/2023	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9	<1.9
4/6/2023	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<1.9	<1.9
4/6/2023	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/6/2023	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9	<1.9
1/12/2023	Perfluorooctane sulfonate (PFOS)	2	2.1
1/12/2023	Perfluorooctanoic acid (PFOA)	2.4	2.2
1/12/2023	Perfluoroundecanoic acid (PFUnA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/12/2023	Perfluorohexanoic acid (PFHxA)	<1.9	<1.9
1/12/2023	Perfluorododecanoic acid (PFDoA)	<1.9	<1.9
1/12/2023	Perfluorodecanoic acid (PFDA)	<1.9	<1.9
1/12/2023	Perfluorohexanesulfonic acid (PFHxS)	<1.9	<1.9
1/12/2023	Perfluorobutanesulfonic acid (PFBS)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/12/2023	Perfluoroheptanoic acid (PFHpA)	<1.9	<1.9
1/12/2023	Perfluorononanoic acid (PFNA)	<1.9	<1.9
1/12/2023	Perfluorotetradecanoic acid (PFTeDA)	<1.9	<1.9
1/12/2023	Perfluorotridecanoic acid (PFTrDA)	<1.9	<1.9
1/12/2023	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/12/2023	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<1.9	<1.9
1/12/2023	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9	<1.9
1/12/2023	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<1.9	<1.9
1/12/2023	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/12/2023	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9	<1.9
10/12/2022	Perfluorooctane sulfonate (PFOS)	2.3	2.2
10/12/2022	Perfluorooctanoic acid (PFOA)	2.3	2.2
10/12/2022	Perfluoroundecanoic acid (PFUnA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/12/2022	Perfluorohexanoic acid (PFHxA)	<1.9	<1.9
10/12/2022	Perfluorododecanoic acid (PFDoA)	<1.9	<1.9
10/12/2022	Perfluorodecanoic acid (PFDA)	<1.9	<1.9
10/12/2022	Perfluorohexanesulfonic acid (PFHxS)	<1.9	<1.9
10/12/2022	Perfluorobutanesulfonic acid (PFBS)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/12/2022	Perfluoroheptanoic acid (PFHpA)	<1.9	<1.9
10/12/2022	Perfluorononanoic acid (PFNA)	<1.9	<1.9
10/12/2022	Perfluorotetradecanoic acid (PFTeDA)	<1.9	<1.9
10/12/2022	Perfluorotridecanoic acid (PFTrDA)	<1.9	<1.9
10/12/2022	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/12/2022	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<1.9	<1.9
10/12/2022	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9	<1.9
10/12/2022	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<1.9	<1.9
10/12/2022	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
10/12/2022	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9	<1.9
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/13/2022	Perfluorooctane sulfonate (PFOS)	2.3	2.2
7/13/2022	Perfluorooctanoic acid (PFOA)	2.1	2.3

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/13/2022	Perfluoroundecanoic acid (PFUnA)	<1.9	<1.9
7/13/2022	Perfluorohexanoic acid (PFHxA)	<1.9	<1.9
7/13/2022	Perfluorododecanoic acid (PFDoA)	<1.9	<1.9
7/13/2022	Perfluorodecanoic acid (PFDA)	<1.9	<1.9
7/13/2022	Perfluorohexanesulfonic acid (PFHxS)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/13/2022	Perfluorobutanesulfonic acid (PFBS)	<1.9	<1.9
7/13/2022	Perfluoroheptanoic acid (PFHpA)	<1.9	<1.9
7/13/2022	Perfluorononanoic acid (PFNA)	<1.9	<1.9
7/13/2022	Perfluorotetradecanoic acid (PFTeDA)	<1.9	<1.9
7/13/2022	Perfluorotridecanoic acid (PFTrDA)	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/13/2022	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<1.9	<1.9
7/13/2022	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<1.9	<1.9
7/13/2022	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.9	<1.9
7/13/2022	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<1.9	<1.9
7/13/2022	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<1.9	<1.9

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
7/13/2022	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.9	<1.9
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2022	Perfluorooctane sulfonate (PFOS)	2.1	2.1
4/20/2022	Perfluorooctanoic acid (PFOA)	2.4	2.5

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2022	Perfluoroundecanoic acid (PFUnA)	<1.8	<1.8
4/20/2022	Perfluorohexanoic acid (PFHxA)	<1.8	<1.8
4/20/2022	Perfluorododecanoic acid (PFDoA)	<1.8	<1.8
4/20/2022	Perfluorodecanoic acid (PFDA)	<1.8	<1.8
4/20/2022	Perfluorohexanesulfonic acid (PFHxS)	<1.8	<1.8

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2022	Perfluorobutanesulfonic acid (PFBS)	<1.8	<1.8
4/20/2022	Perfluoroheptanoic acid (PFHpA)	<1.8	<1.8
4/20/2022	Perfluorononanoic acid (PFNA)	<1.8	<1.8
4/20/2022	Perfluorotetradecanoic acid (PFTeDA)	<1.8	<1.8
4/20/2022	Perfluorotridecanoic acid (PFTrDA)	<1.8	<1.8

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2022	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<1.8	<1.8
4/20/2022	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<1.8	<1.8
4/20/2022	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.8	<1.8
4/20/2022	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<1.8	<1.8
4/20/2022	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<1.8	<1.8

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2022	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.8	<1.8
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/19/2022	Perfluorooctane sulfonate (PFOS)	2.1	2
1/19/2022	Perfluorooctanoic acid (PFOA)	2.3	2.3

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/19/2022	Perfluoroundecanoic acid (PFUnA)	<1.8	<1.8
1/19/2022	Perfluorohexanoic acid (PFHxA)	<1.8	<1.8
1/19/2022	Perfluorododecanoic acid (PFDoA)	<1.8	<1.8
1/19/2022	Perfluorodecanoic acid (PFDA)	<1.8	<1.8
1/19/2022	Perfluorohexanesulfonic acid (PFHxS)	<1.8	<1.8

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/19/2022	Perfluorobutanesulfonic acid (PFBS)	<1.8	<1.8
1/19/2022	Perfluoroheptanoic acid (PFHpA)	<1.8	<1.8
1/19/2022	Perfluorononanoic acid (PFNA)	<1.8	<1.8
1/19/2022	Perfluorotetradecanoic acid (PFTeDA)	<1.8	<1.8
1/19/2022	Perfluorotridecanoic acid (PFTrDA)	<1.8	<1.8

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/19/2022	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<1.8	<1.8
1/19/2022	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<1.8	<1.8
1/19/2022	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA)	<1.8	<1.8
1/19/2022	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<1.8	<1.8
1/19/2022	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<1.8	<1.8

<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
4/20/2026	Perfluorooctane sulfonate (PFOS)	1.8	1.8
4/20/2026	Perfluorooctanoic acid (PFOA)	1.7	1.9
4/20/2026	Perfluoroundecanoic acid (PFUnA)	<0.3	<0.4
4/20/2026	Perfluorohexanoic acid (PFHxA)	1.1	1.2
4/20/2026	Perfluorododecanoic acid (PFDoA)	<0.4	<0.4
4/20/2026	Perfluorodecanoic acid (PFDA)	<0.3	<0.3
4/20/2026	Perfluorohexanesulfonic acid (PFHxS)	0.6	0.6
4/20/2026	Perfluorobutanesulfonic acid (PFBS)	<0.04	<0.4
4/20/2026	Perfluoroheptanoic acid (PFHpA)	0.9	0.9
4/20/2026	Perfluorononanoic acid (PFNA)	<0.5	<0.5
4/20/2026	Perfluorotetradecanoic acid (PFTeDA)	<0.6	<0.6
4/20/2026	Perfluorotridecanoic acid (PFTrDA)	<0.5	<0.5
4/20/2026	N-methyl Perfluorooctanesulfonamidoacetic acid (NMeFOSAA)	<0.4	<0.4
4/20/2026	N-ethyl Perfluorooctanesulfonamidoacetic acid (NEtFOSAA)	<0.5	<0.5
4/20/2026	Hexafluoropropylene Oxide Dimer Acid (HFPO-DA) (GenX)	<0.3	<0.3
4/20/2026	9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	<0.3	<0.3
4/20/2026	11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	<0.3	<0.3
4/20/2026	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<0.2	<0.2
4/20/2026	Hazard Index EPA only= (GenX/10 ppt)+(PFBS/2000 ppt)+(PFNA/10ppt)+PFHxS/9.0 ppt)= running annual average must be <1.0	0.07	0.07
<u>Date</u>	<u>Analyte</u>	<u>TAP</u>	<u>RAW</u>
1/19/2022	4,8-Dioxa-3H-perfluorononanoic acid (ADONA)	<1.8	<1.8