




# 2016 Annual Report



**Evanston Public Works Agency**  
**Water Production Bureau**  
**Water and Sewer Utilities**  
**Serving the Community for 142 Years**



**Cover photos, clockwise from top left:** National Drinking Water Week 3rd Grade Art Contest Winners - People's Choice Award, Peter Jankowski, St. Anthanasius Elementary School, Mayor's Choice Award, Ryan Hecker, Willard Elementary School, Water Spirit Award, Lucy Marinacci, St. Anthanasius Elementary School.



# Table of Contents

## Introduction

---

Public Works Agency Annual Accomplishments and Performance Measures	1
Water Treatment Plant Data	4
Water Treatment Schematic	5
Water Works Improvements	6
Service Area and Population	10
Pumpage to Distribution	11
Water Revenues	12
Water Operating and Maintenance Expenses	13

## Pumping

---

Monthly and Average Daily Pumpage	15
Annual Pumpage	16
Average Daily per Capita Consumption	17
Maximum Day and Peak Hour Pumpage	18
Maximum Pumpage and Demand Days	19
Energy Costs	20

## Filtration

---

Chemical Treatment: Chemicals Used and Cost	23
Annual Chemical Costs	24
Filter Operations	25
Bacteriological Water Analysis	26
Taste & Odor, Turbidity, Temperature and Fluoride	27
Chlorine Residual	28
pH, Alkalinity and Hardness	29
Detected Substances: 2016 Water Quality Data	30
Non-Detected Contaminants: 2016 Water Quality Data	32
Lead and Copper Statement	34
Definitions and General Explanations for Use with Water Quality Data	35

## **Distribution**

---

Fire Hydrants: System Data and Maintenance	37
Water Distribution System Valves: System Data and Maintenance	38
Water Mains: System Data and Maintenance	39
Water Services: System Data and Maintenance	40
Breakdown of In-House Maintenance Costs	40
Water Main Improvements	41
Leak Detection Program	42
Cross Connection Control	43

## **Metering**

---

Advanced Metering Infrastructure (AMI) System	45
Transmitter Tower Locations	46
Water Meter Inventory	47
Water Rates for Evanston Customers	47
Water Customer Classes and Metered Usage	48
Water Usage Breakdown for Evanston Customers	49

## **Sewer**

---

Sewer Revenues	51
Sewer Operating and Maintenance Expenses	52
Major Combined Sewer System	53
Major Relief Sewer System	54
Major Storm Sewer System	55
Sewer Mains: System Data and Maintenance	56
Length of Sewer Mains by Type and Diameter	57
Sewer Structures: System Data and Maintenance	58
Breakdown of In-House Maintenance Costs	59
Sewer Mains Rehabilitated (Lined)	60

# Evanston Water and Sewer Utilities Annual Accomplishments and Performance Measures

## Introduction

The Evanston Public Works Agency manages water and sewer operations for the City of Evanston. The Water Utility is responsible for operation and maintenance of the Water Treatment Plant, which supplies water to over 400,000 people in Evanston and six other communities. The Water Utility also operates and maintains more than 155 miles of water mains, 2,000 valves, and 1,500 fire hydrants in the Evanston distribution system. This division also manages leak detection and cross connection control programs to minimize water loss and ensure the safety of the community's water supply.

The Sewer Utility is responsible for operation and maintenance of the sewer conveyance systems in Evanston, including a combined sewer system, a relief combined sewer system, and a storm sewer system. These systems are comprised of over 200 miles of sewer mains ranging in size from less than 6-inch diameter to 120-inch diameter, including over 5,500 manhole structures and over 9,000 drainage structures.

The Public Works Agency also coordinates with ComEd, Nicor, AT&T, and other private utilities on behalf of Evanston residents and businesses to help resolve service issues and improvement needs.

The Department's total FY 2016 budget was approximately \$56.5 million (\$41.1 million Water Fund and \$15.4 million Sewer Fund). Public Works Agency staff includes 54.83 full-time equivalents (FTEs).

## Year-to-Year Public Works Agency Metrics

	2014	2015	2016
Total Water Pumped (millions of gallons)	13,428	13,424	14,519
Fire Hydrants Repaired or Replaced	330	64	345
Water Main Valves Repaired or Replaced	53	71	56
Water Main Replaced or Rehabilitated (miles)	1.7	0.89	2.27
Large Diameter Sewer Rehabilitated (feet)	5,356	5,032	1,908
Small Diameter Sewer Rehabilitated (feet)	6,703	6,298	5,845
Sewer Mains Inspected (feet of pipe)	97,347	96,077	80,094
Sewer Mains Cleaned (feet of pipe)	151,091	150,406	225,966
Sewer Structures Repaired or Replaced	76	91	98

## **2016 Major Accomplishments**

### *Maintained High Quality of Service*

Remained a leader in the public drinking water industry by providing high quality service to over 400,000 customers in six communities, including vigilantly monitoring the quality and quantity of water provided to our customers.

### *Major Water Treatment Facility Improvements*

Assured the quality and reliability of the potable water supply by the initiation of major water treatment plant improvements including chemical feed, treatment process reliability improvements, and Finished Water Storage Improvements to address structural deterioration the City's largest clearwell built in 1934.

### *Digitalization of Plant Information*

The initiation of a Computerized Maintenance Management System (CMMS) at the water treatment plant to more effectively manage long-term maintenance and replacement of critical treatment plant equipment and structures.

### *Water Supply Expanded*

Expanded Evanston's wholesale water customer base by successfully negotiating an agreement with both Morton Grove and Niles.

### *Completed Water Distribution and Expansion*

Improved water distribution system reliability and reduced water loss by expanding on the current water main replacement and water main leak detection programs. Goals were to supplement water main replacement with water main lining where feasible, to improve upon our historical 1% annual water main renewal rate, and to survey the entire distribution system for leaks on an annual cycle. Completed other major distribution system improvements including rehabilitation and replacement of water mains on Sheridan Road between Lincoln Street and Chicago Avenue.

### *Coordinated Efficient Project Funding*

Coordinated capital improvement projects with the Street Resurfacing Program and with TIF District improvement projects to ensure cost-effective and efficient use of capital improvement funding.

### *Designed and Funded Large Diameter Sewer Rehabilitation*

Performed engineering design and secured state low-interest loan funding for two additional large diameter sewer rehabilitation projects scheduled for 2016 and 2017.

### *Continued Small Diameter Sewer Rehabilitation*

Continued the annual small diameter sewer CIPP rehabilitation program at a rate of at least 1% of the combined sewer system rehabilitated per year.

### *Prevented Sewer Deterioration with Rehabilitation Program*

Implemented a large scale sewer structure rehabilitation program that addressed deterioration of sewer structures on arterial streets.

*Continued Coordination with Street Resurfacing Program*

Continued to coordinate the inspection and repair of sewer main and drainage structures prior to the street resurfacing program.

*Continued Preventative Measures for Sewer Mains*

Continued preventative maintenance cleaning and inspection of sewer mains and drainage structures.

*Completed Combined and Storm Sewer Inspections*

Continued to perform inspections of combined and storm sewer outfalls in accordance with IEPA requirements.

*Increased Storm Water Management Initiatives*

Increased storm water management initiatives in compliance with requirements for National Pollution Discharge Elimination System (NPDES) permit and Municipal Separate Storm Sewer System (MS4) permit.

**2016 Major Goals and Initiatives**

*Design and Fund Large Diameter Sewer Rehabilitation*

Perform engineering design and secure State low-interest loan funding for a large diameter sewer rehabilitation project scheduled for 2017.

*Small Diameter Sewer Rehabilitation*

Continue the annual small diameter sewer CIPP rehabilitation program at a rate of at least 1% of the combined sewer system rehabilitated per year.

*Arterial Street Sewer Structure Rehabilitation*

Continue the sewer structure rehabilitation program to address deterioration of sewer structures on arterial streets.

*Coordination with Street Resurfacing Program*

Continue to coordinate the inspection and repair of sewer mains and drainage structures in advance of the street resurfacing program.

*Continue Best Management Practices for Sewer Mains*

Continue preventative maintenance cleaning and inspection of sewer mains and drainage structures.

*Combined and Storm Sewer Regulatory Inspections*

Continue to perform inspection of combined and storm sewer outfalls in accordance with IEPA requirements.

*Increase Storm Water Management Initiatives*

Increase storm water management initiatives in compliance with requirements for National Pollution Discharge Elimination System (NPDES) permit and Municipal Separate Storm Sewer System (MS4) permit.

## Water Treatment Plant Data

### Intakes

36/42" – 5,946' long, 28' deep

48" – 5,300' long, 28' deep

54" – 5,340' long, 28' deep

### Suction Wells

2 – 22' diameter x 74' deep with traveling screens

1 – 20' diameter x 52.5' deep

### Low Lift Pumps

2 – 30 mgd, electric motor driven

3 – 15 mgd, dual drive, electric/natural gas

1 – 30 mgd, dual drive, electric/natural gas

Total capacity of 135 mgd

Emergency standby capacity of 75 mgd

### Flash Mix Basin

14.75' x 14.75' x 31.58' deep

Single vertical shaft mixer

Counter-flow rotation

Application point for alum, chlorine, fluoride, polymer, and carbon

Rated capacity 108 mgd w/ partial bypass

### Slow Mix/Settling Basins

Four double-deck basins with series flow

2 – 2.865 MG capacity, five 60' shafts per basin, 4 paddle wheel sections

2 – 4.3 MG capacity, eight 60' shafts per basin, 4 paddle wheel sections

Retention time at 108 mgd (flash mix capacity) is 3 hours and 11 minutes

### Treated Water Elevated Storage

South – 5.0 MG, 640 Hartrey Avenue

North – 7.5 MG, 2536 Gross Point Road

### Filters

Anthracite-capped rapid sand filters

12 – 3.19 mgd, 738 ft<sup>2</sup> each, surface loading rate of 3 gpm/ft<sup>2</sup>

12 – 8.01 mgd, 1,391 ft<sup>2</sup> each, surface loading rate of 5 gpm/ft<sup>2</sup>

Total rated capacity of 134 mgd

Automatic surface and backwash system on all 24 filters

### Treated Water Ground Storage

8 clearwells beneath filters – 4.4 MG total

1 clearwell beneath NU parking lot – 5.0 MG

Total Plant Storage – 9.4 MG

### High Lift Pumps

1 – 15 mgd, electric motor driven

2 – 25 mgd, electric motor driven

1 – 10 mgd, dual drive, electric/natural gas

2 – 15 mgd, dual drive, electric/natural gas

1 – 22 mgd, dual drive, electric/natural gas

1 – 20 mgd, natural gas engine

Total capacity of 147 mgd

Emergency standby capacity of 82 mgd

### Wash Water Pumps

2 – 20 mgd

2 – 10 mgd

### Detention Tank


80' x 192' x 12' deep, divided in 2 sections

Total capacity of 1.1 MG

1 – submersible sludge pump at 700 gpm

**Legend:** MG = million gallons; mgd = million gallons per day; gpm = gallons per minute

# Water Treatment Schematic



The Evanston Water Treatment Plant provides conventional treatment (mixing, flocculation, sedimentation, and filtration). Filtered water gravitates to 8 clearwells with a total volume of 4.4 MG and a separate 5.0 MG clearwell. Total filtration capacity is 134 mgd. Firm filtration capacity (one filter out of service) is 126 mgd. Rated capacity of the plant is limited by the size of process piping to 108 mgd.

Volume (MG)	0.109	2.384	13.516	1.730	9.560*
-------------	-------	-------	--------	-------	--------

Notes:  
\*based on 8.0' depth

## **Water Works Improvements (1874 to 2016)**

- 1874** Evanston Community Water System established
- 1913** Constructed 12 mgd filter plant
- 1923** Expanded filter plant to 24 mgd
- 1934** Constructed 5.0 million gallon underground reservoir at plant site
- 1944** Contracted to supply water to Skokie
- 1949** Constructed high lift (finished water) pumping station  
Expanded filter plant to 48 mgd  
Constructed slow mix basins 1 and 2
- 1956** Constructed 48" intake and low lift (raw water) pump station  
Constructed 36" feeder main to Skokie
- 1964** Expanded filter plant to 72 mgd  
Constructed additional 36" feeder main to Skokie  
Constructed slow mix basins 3 and 4
- 1971** Installed 20 mgd high lift pump and natural gas engine
- 1974** Constructed filter wash water detention basin, 1.1 MG capacity
- 1976** Constructed 54" intake, 5,340 feet in length  
Extended 48" intake to 5,300 feet in length
- 1981** Constructed material storage building at south water tank yard  
Installed 3 new boilers (2 – 50 HP and 1 – 20 HP)  
Replaced 5 kV switchgear and motor starter equipment for low lift pumps  
Upgraded slow mix equipment in basins 1 and 2
- 1982** Installed two 30 mgd low lift pumps  
Replaced 5 kV motor starter center for high lift pumps
- 1983** Constructed new chemical building and chemical feed system  
Installed a 500 kW emergency generator  
Rehabilitated six 1914 and six 1924 filters to increase rate to 3 MGD per filter
- 1984** Constructed 5 MG standpipe with booster station to replace the 1.5 MG elevated tank in southwest Evanston

- 1985** Began selling water to Northwest Water Commission at the rate of 10 MGD  
Installed dual drive 22 MGD high lift pump and new piping  
Installed two 48" diameter pipes from reservoir to east side of high lift suction tunnel  
Completed system automation which provided a microprocessor-based digital control system to perform control and supervisory functions
- 1986** Constructed a 7.5 MG standpipe with booster station to replace the 1.0 MG elevated tank in northwest Evanston  
Began pumping to Northwest Water Commission reservoir in Des Plaines
- 1988** Installed two 700 gpm sludge pumps with automatic samplers in the settling basins along with 3,400 feet of 8" diameter sludge main from the Filtration Plant to the MWRD interceptor at Lincoln Street and Asbury Ave
- 1989** Completed filter control upgrade to microprocessors
- 1990** Turndown and extension of 48" raw water intake lines into North and South suction wells  
Upgraded west filter influent valves from 16" to 24"
- 1991** Upgraded electrical substation and switchgear to 3,750 kVA  
Upgraded west filter effluent piping
- 1992** Installed chlorine feed system to intakes for zebra/quagga mussel control  
Installed a 15 MGD high lift pump to replace one 8 MGD pump and one 6 MGD pump  
Installed two 48" diameter butterfly valves on suction piping from reservoir to high lift suction wells  
Installed hydrofluosilicic acid tank and feed system in garage #6  
Installed 60" diameter flash mix bypass pipe to influent duct of settling basins  
Replaced slow mix equipment and flushing system in basins 3 and 4  
Replaced 480 V filter plant switchgear  
Installed blended phosphate system and initiated blended phosphate treatment for corrosion control
- 1994** Constructed new chemical storage and handling building
- 1995** Replaced Low Lift Pump #6 gasoline engine with natural gas engine
- 1996** Replaced 1949 filter building roof  
Constructed loading dock on 1913 filter building
- 1997** Replaced High Lift Pump #2 gasoline with a natural gas engine
- 1998** Replaced Low Lift Pump #5 and #7 dual drive gasoline engines with natural gas fueled engines


- 2000** Installed individual effluent turbidimeters on all 24 filters
- 2001** Converted High Lift Pump #3 to dual drive  
Replaced filter bottoms and rehabbed six filters in 1948 filter addition
- 2002** Completed installation of automatic fixed radio meter reading system  
Replaced effluent settling basin sluice gates with rectangular butterfly valves
- 2003** Installed uninterruptible power supply to filtration and pumping equipment
- 2004** Constructed garages east of the settling basins  
Constructed an access way to the chemical building from filtration division  
Installed a scrubber
- 2005** Replaced Low Lift Pump #4 gasoline engine with natural gas engine
- 2006** Replaced Low Lift Pump #7
- 2008** Renovated administrative offices  
Expanded filter shop area
- 2009** Implemented AQUAS (Harris) Utility Billing System  
Installed anchor ice and zebra mussel control systems in 54" intake
- 2010** Installed a 25 kW solar energy facility on the high lift pump station roof
- 2012** Rehabilitated Filters 19-24 with new media, underdrains, and backwash equipment  
Rehabilitated the 1963 filter building structure and roof  
Replaced all windows in the high lift pump station  
Replaced electrical switchgear in high lift pump station
- 2013** Modified electrical distribution equipment and settings on protective devices throughout the water treatment plant to reduce arc flash hazards  
Conducted comprehensive maintenance and evaluation of electrical Switchgears
- 2014** Replaced five roofs: Boiler Room, Low Lift Pumping Station, Chemical Building, and 1948 Filter Building (2 roofs), replaced master flow meter on the 48" diameter feeder main to Evanston and Skokie
- 2015** Improvements to one of the water plant intakes, upgrade/replacement of the City's automatic meter reading and billing system, and chlorination equipment replacement.
- 2016** Completed standpipe painting and replaced four roofs (1964 Filter Building Clerestory, 1948 Filter Building Clerestory, Filter Cross Corridor & Chlorine Building).

**Notes:** MG = million gallons  
mgd = million gallons per day  
HP = horsepower  
kV = kilovolt  
kW = kilowatt  
kVA = kilovolt-ampere

## Service Area & Population


	Area (Square Miles)	2016 Persons*
Evanston	7.8	75,527
Skokie	10	64,821
<b>NORTHWEST WATER COMMISSION</b>		
Arlington Heights	16.6	75,926
Buffalo Grove	9.5	41,503
Palatine	13.6	69,308
Wheeling	8.7	38,079
Des Plaines	14.4	58,677
<b>Total Served</b>	<b>80.6</b>	<b>423,841</b>

\* U.S. Census Bureau, 2015 Estimate




## Pumpage to Distribution

### 2016 Pumpage to Distribution (MG)



2016 Total Pumpage: 14,518,851,000 gallons


### 2015 Pumpage to Distribution (MG)



2015 Total Pumpage: 13,423,806,000 gallons

## Water Revenues\*

	2015	2016
Evanston Water Sales	\$6,651,000	\$6,987,878
Skokie Water Sales	\$2,800,000	\$2,941,912
NWC Water Sales	\$5,130,000	\$5,695,812
Debt Proceeds	\$3,525,000	\$230,000
Miscellaneous Revenue**	\$527,375	\$629,414
<b>Total Water Revenue</b>	<b>\$18,635,390</b>	<b>\$16,487,032</b>




\* Financial data are based on actual expenses and do not include audit adjustments such as depreciation and inventory. For audited financial records, see the Comprehensive Annual Financial Report for the City of Evanston, <http://www.cityofevanston.org/transparency/budget-financial-reports/>.

\*\* Miscellaneous Revenue includes cross connection control fees, investment earnings, property sales and rentals, fees, outside work, grants, development fees, phosphate sales, and merchandise sales.

## Water Operating & Maintenance Expenses\*

	2015	2016
General Support	\$1,117,602	\$397,716
Pumping	\$2,392,399	\$2,533,001
Filtration	\$2,293,890	\$2,427,538
Distribution	\$1,629,360	\$1,162,091
Meter Maintenance	\$202,759	\$203,818
Other Operating Expenses**	\$4,382,080	\$7,097,052
<b>Total</b>	<b>\$12,018,091</b>	<b>\$13,821,215</b>



\* Financial data are based on actual expenses and do not include audit adjustments such as depreciation and inventory. For audited financial records, see the Comprehensive Annual Financial Report for the City of Evanston, <http://www.cityofevanston.org/transparency/budget-financial-reports/>.

\*\*Other Operating Expenses include capital outlay, interfund transfers (general and insurance), and other operating expenses.

# Pumping


Evanston's Pumping Division manages the City's three Lake Michigan water supply intakes, pumping of raw water to the start of the water treatment process; pumping of treated water to retail customers in Evanston as well as wholesale customers; and operation and maintenance of Evanston's treated water storage facilities and remote water pumping stations. This division also monitors water storage tanks in the Village of Skokie, as well as controlling the rate of water supply to the Northwest Water Commission.



High Lift Pumping Station at the Evanston Water Treatment Plant

There is at least one pump operating at the Evanston Water Treatment Plant at all times, to ensure that a sufficient quantity of water is always available for public consumption and firefighting. There is always at least one water operator present at the Pumping Station to control water supply and pressure and respond to emergencies.

Evanston has been pumping drinking water from the site of the existing water treatment plant on Lincoln Street since 1874. The original "water works" consisted of a coal-fired steam engine and a single pump with a capacity of 2 million gallons per day. Construction of a pumping station to serve the entire City drastically improved Evanston's ability to fight fires and allowed the City to reliably deliver Lake Michigan water to homes and businesses on demand for the first time.



Evanston's original pumping station in 1874

## 2016 Monthly Pumpage (MG)

Month	Lake	Wash	Net	Finished	Pumpage To		
	Water	Water	Raw Water	Water	Evanston	Skokie	N.W.C.
	Pumpage	Recycled	Pumpage	Pumpage			
Jan-16	1,086.931	14.906	1,101.837	1,104.406	221.282	236.778	646.346
Feb-16	981.320	13.083	994.403	1,003.059	239.849	205.449	557.761
Mar-16	1,006.181	13.824	1,020.005	1,036.734	218.994	224.519	593.221
Apr-16	1,021.884	13.316	1,035.200	1,051.962	223.289	222.227	606.446
May-16	1,228.108	19.911	1,248.019	1,258.027	250.406	239.398	768.223
Jun-16	1,301.329	28.010	1,329.339	1,325.218	268.991	252.723	803.504
Jul-16	1,425.218	29.663	1,454.881	1,462.990	301.121	274.199	887.670
Aug-16	1,394.120	31.256	1,425.376	1,425.783	300.573	270.068	855.142
Sep-16	1,271.030	21.755	1,292.785	1,297.671	277.058	239.415	781.198
Oct-16	1,206.712	18.985	1,225.697	1,224.607	267.044	216.809	740.754
Nov-16	1,106.157	13.555	1,119.712	1,130.757	250.221	194.252	686.284
Dec-16	1,172.180	12.756	1,184.936	1,197.637	240.530	219.559	737.548
<b>Total</b>	<b>14,201.170</b>	<b>231.020</b>	<b>14,432.190</b>	<b>14,518.851</b>	<b>3,059.358</b>	<b>2,795.396</b>	<b>8,664.097</b>


## 2016 Average Day Pumpage (MGD)

Month	Lake	Wash	Net	Finished	Pumpage To		
	Water	Water	Raw Water	Water	Evanston	Skokie	N.W.C.
	Pumpage*	Recycled	Pumpage	Pumpage			
Jan-16	35.062	0.481	35.543	35.626	7.138	7.638	20.850
Feb-16	35.047	0.467	35.514	35.824	8.566	7.337	19.920
Mar-16	34.400	0.446	32.903	33.443	7.064	7.243	19.136
Apr-16	33.939	0.444	34.507	35.065	7.443	7.408	20.215
May-16	39.616	0.430	33.394	40.582	8.078	7.723	24.781
Jun-16	43.378	0.934	44.311	44.174	8.966	8.424	26.783
Jul-16	45.975	0.957	46.932	47.193	9.714	8.845	28.635
Aug-16	44.972	1.008	45.980	45.993	9.696	8.712	27.585
Sep-16	42.368	0.725	43.093	43.256	9.235	7.981	26.040
Oct-16	38.926	0.612	39.539	39.503	8.614	6.994	23.895
Nov-16	36.872	0.452	37.324	37.692	8.341	6.475	22.876
Dec-16	37.812	0.411	38.224	38.633	7.759	7.083	23.792
<b>Average</b>	<b>38.907</b>	<b>0.633</b>	<b>39.540</b>	<b>39.778</b>	<b>8.382</b>	<b>7.659</b>	<b>23.737</b>

Note: "Pumpage to Evanston" includes process and domestic water uses at the water treatment plant.

## Annual Pumpage (MG)

Year	Lake Water Pumpage	Wash Water Recycled	Total Raw Water Pumpage	Finished Water Pumpage	Pumpage To		
					Evanston	Skokie	N.W.C.
2016	14,201.170	231.020	14,432.190	14,375.415	3,059.358	2,795.396	8,664.097
2015	13,471.823	200.285	13,672.108	13,423.806	2,790.010	2,786.896	7,846.900
2014	13,416.872	239.547	13,656.419	13,427.979	2,719.978	2,766.348	7,941.653
2013	13,925.102	247.609	14,172.711	13,814.461	2,930.278	2,787.256	8,096.927
2012	14,817.637	322.302	15,110.465	14,627.115	2,939.417	3,068.004	8,619.694
2011	13,939.618	212.426	14,152.042	13,941.167	2,991.848	2,866.652	8,082.667
2010	14,087.849	218.251	14,306.100	14,268.257	2,701.569	3,094.554	8,472.134
2009	14,363.047	193.841	14,556.888	14,350.335	3,140.898	2,829.824	8,379.613
2008	14,872.552	134.595	15,007.147	14,693.877	3,142.816	2,961.341	8,589.720
2007	15,905.381	192.088	16,097.469	15,771.451	3,207.422	3,564.781	8,999.248



## Average Daily per Capita Consumption




Year	Evanston		Skokie		NWC		Total	
	Population	Per Capita Use (gpcd)						
2016	75,527	111	64,821	118	283,493	84	423,841	94
2015	75,570	101	65,176	117	225,137	95	365,883	101
2014	75,570	99	65,176	116	225,137	97	365,883	101
2013	75,570	106	65,176	117	225,137	99	365,883	103
2012	74,486	105	64,784	130	222,802	106	362,072	110
2011	74,486	107	64,784	121	222,802	99	362,072	105
2010	74,486	97	64,784	131	222,802	104	362,072	107
2009	74,360	110	63,333	122	221,364	104	359,057	108
2008	74,360	114	63,333	128	221,364	106	359,057	112
2007	74,360	116	63,333	154	221,364	111	359,057	120

## Maximum Pumpage to Distribution

Year	Max Day Pumpage Volume (MG)	Peak Hour Pumpage Rate (MGD)	Peak Hour Pumpage Volume (MG)
2016	55.084	57.264	2.386
2015	53.300	54.816	2.284
2014	48.907	55.848	2.327
2013	56.946	72.072	3.003
2012	69.210	85.680	3.570
2011	66.096	75.144	3.131
2010	57.020	89.520	3.730
2009	58.940	67.440	2.810
2008	57.478	69.480	2.895
2007	65.997	70.632	2.943

Historical Maximum Day Pumpage: 95.154 MG on July 7, 1989

# Maximum Day and Peak Hour Pumpage



## Maximum Pumpage Days (MGD)

Year	Maximum Day Pumpage To			
	Distribution	Evanston	Skokie	NWC
2016	July 20th 55.084	July 20th 12.561	August 10th 10.37	July 22nd 32.593
2015	August 14th 53.300	August 6th 11.852	August 14th 10.95	August 2nd 30.414
2014	August 4th 48.907	August 15th 9.875	August 4th 10.87	August 4th 30.871
2013	August 28th 56.946	August 28th 12.585	August 28th 11.209	August 27th 33.374
2012	July 17th 69.210	July 17th 18.580	July 17th 13.579	July 6th 43.775
2011	July 18th 66.096	July 18th 12.614	July 18th 13.724	July 19th 40.820
2010	July 17th 57.020	July 29th 13.643	August 20th 12.957	July 19th 34.661
2009	August 14th 58.940	August 13th 13.992	August 14th 11.495	August 6th 34.725
2008	July 30th 57.478	July 30th 11.788	July 30th 11.495	July 29th 33.670
2007	August 2nd 65.997	August 2nd 17.774	June 11th 16.493	August 2nd 35.946

Historical Maximum Day Pumpage to Distribution: 95.154 MG on July 7, 1989

## Energy Costs

### Electric Power - Kilowatt Hours (kWh) Used

Year	Total kWh	Total Cost*	Average Unit Cost per kWh	kWh Per Million Gallons Pumped
2016	11,450,522	\$943,798	\$0.082	797
2015	10,365,952	\$810,030	\$0.078	772
2014	10,897,123	\$787,444	\$0.072	812
2013	11,529,489	\$779,226	\$0.068	835
2012	13,706,324	\$924,422	\$0.067	937

\* 2012 cost is higher than usual due to increased pumpage during a drought.

### Natural Gas Used for Pumping and Emergency Engines\*

Year	Therms	Total Cost**	Average Unit Cost per Therm
2016	121,018	\$58,307	\$0.482
2015	132,575	\$86,033	\$0.649
2014	129,481	\$86,926	\$0.671
2013	124,954	\$83,901	\$0.671
2012	225,100	\$116,272	\$0.517



\* Includes natural gas purchase and delivery charges.

\*\* 2011 cost is elevated due to switchgear fire, which required extended emergency generator use.

### Total Energy Cost (Electric & Gas)

Year	Total Cost	Cost Per Million Gallons Pumped
2016	\$1,002,105	\$69.71
2015	\$896,063	\$66.75
2014	\$874,370	\$65.12
2013	\$863,127	\$62.48
2012	\$957,517	\$65.46


## Energy Costs



\* Energy costs increased in 2012 due to increased pumping during the summer drought.

# Filtration

The Filtration Division manages the water treatment process, including chemical addition, sedimentation, filtration, and disinfection. This involves operation and maintenance of 5 chemical feed systems, 4 settling basins, 24 filters, and numerous pipes, valves, and instrumentation systems. There is always at least one state-certified water treatment operator at the filtration plant at all times, who monitors instrumentation and water quality testing results to ensure that the water is always safe to drink.



Filters 1 – 12 in operation at the Evanston Water Treatment Plant

This division also includes the City's Water Quality Laboratory, which monitors Evanston's drinking water for compliance with state and federal water quality regulations and completes regular reporting to the public and the Illinois Environmental Protection Agency to certify the quality of Evanston's water.

Full-scale water treatment began in Evanston in 1914. The process included settling basins with chemical addition to allow larger contaminants to drop out of the water by gravity, filtration to remove smaller contaminants, and disinfection with chlorine. The new treatment process virtually eliminated waterborne disease in Evanston. This process was state-of-the-art at the time, and Evanston was one of the first communities in the region to adopt full-scale water treatment with rapid sand filtration. Though only the filters from the 1914 treatment plant survive to this day, Evanston's water treatment process still follows the same steps.




Filters 1 – 12, photo taken in 1924

## Chemical Treatment: Chemicals Used and Costs

	Chemical Feed (lbs/MG)			Unit Cost	Pounds per Year	Total Cost	Cost per MG Treated
	Avg Daily	Max Day	Min Day				
<b>Aluminum Sulfate</b>							
2016	56.0	90.6	39.8	\$346.15 / dry ton	798,936	\$126,232	\$8.75
2015	51.4	95.1	38.2	\$447.28 / dry ton	686,299	\$153,484	\$11.39
2014	48.1	90.3	39.4	\$447.28 / dry ton	653,896	\$146,237	\$10.71
2013	54.8	97.2	39.5	\$447.28 / dry ton	770,838	\$172,390	\$12.16
2012	55.9	101.6	30.2	\$447.28 / dry ton	830,624	\$185,761	\$12.27
<b>Chlorine</b>							
2016	12.2	16.2	8.9	\$316.00 / ton	177,845	\$30,781	\$2.13
2015	11.9	16.1	6.6	\$318.00 / ton	161,345	\$29,445	\$2.19
2014	11.7	18.4	8.1	\$365.00 / ton	161,480	\$29,470	\$2.16
2013	12.2	17.9	7.6	\$365.00 / ton	176,190	\$32,155	\$2.27
2012	12.0	20.0	7.0	\$424.50 / ton	187,315	\$39,758	\$2.63
<b>Activated Carbon*</b>							
<b>Hydrofluosilic Acid (Fluoride)</b>							
2016	28.3	31.1	0.0	\$412.00 / ton	409,596	\$84,377	\$5.85
2015	37.3	70.7	0.0	\$443.37 / ton	492,533	\$132,738	\$9.85
2014	41.0	45.6	0.0	\$519.00 / ton	558,523	\$150,522	\$11.03
2013	37.7	61.1	29.3	\$539.00 / ton	534,550	\$144,061	\$10.16
2012	36.2	38.2	33.3	\$596.00 / ton	547,011	\$163,009	\$10.77
<b>Polymer</b>							
2016	2.8	4.8	1.9	\$480.00 / ton	39,726	\$9,534	\$0.66
2015	2.5	5.5	1.9	\$578.00 / ton	33,903	\$12,883	\$0.96
2014	2.7	5.0	1.9	\$538.00 / ton	36,832	\$13,996	\$1.03
2013	3.3	6.1	2.3	\$760.00 / ton	46,584	\$17,702	\$1.25
2012	3.4	6.1	2.0	\$870.00 / ton	51,318	\$22,323	\$1.47
<b>Blended Phosphate</b>							
2016	13.6	14.8	11.1	\$4.27 / gallon	198,430	\$73,678	\$5.11
2015	13.1	17.7	11.4	\$4.35 / gallon	173,430	\$75,103	\$5.57
2014	13.2	14.1	10.1	\$4.48 / gallon	177,169	\$76,722	\$5.62
2013	12.5	14.0	11.3	\$4.98 / gallon	173,141	\$74,978	\$5.29
2012	12.3	18.5	11.0	\$5.15 / gallon	181,034	\$81,072	\$5.35

\* Carbon can be fed for taste and odor control, though this has not been necessary since 2005.

# Annual Chemical Costs



## Filter Operations

### Filter Runs

Year	Avg Hours per Filter Run		Total Hours per Year	
	3 MGD	8 MGD	3 MGD	8 MGD
2016	237.5	223.6	93,948	103,703
2015	238.6	229.0	80,514	103,404
2014	226.2	201.8	95,298	104,573
2013	224.5	200.6	95,958	101,536
2012	208.7	171.5	96,000	92,402
2011	229.1	197.3	96,336	88,162
2010	229.2	198.8	96,286	100,046
2009	253.8	239.2	97,313	94,790
2008	266.7	228.5	97,050	100,601
2007	234.9	200.7	91,395	104,530

### Filter Washes

Year	Total Washes per Year		Max # of Washes per Day	
	3 MGD	8 MGD	3 MGD	8 MGD
2016	429	513	6	6
2015	347	462	5	5
2014	429	557	5	7
2013	427	524	7	7
2012	476	611	7	9
2011	430	486	5	6
2010	452	559	7	7
2009	387	409	6	5
2008	369	460	6	6
2007	425	569	6	7

### Wash Water

Year	Total (MG)	Avg Daily %	Max Daily %
2016	239.545	1.60	9.65
2015	200.285	1.49	5.31
2014	243.089	1.78	6.20
2013	248.996	2.13	9.72
2012	321.030	1.49	5.14
2011	211.546	1.53	15.2
2010	223.704	1.02	4.54
2009	149.063	0.95	4.15
2008	145.593	1.15	4.86
2007	192.135	1.01	3.25

# Bacteriological Water Analysis (Membrane Filter Method)

## Report of Evanston Water Quality Control Laboratory

The U.S. Environmental Protection Agency (EPA) standard is based on the presence or absence of total coliform bacteria in a water sample. Evanston is required to collect 80 water samples per month from the distribution system. The EPA requires that no more than 5% of these monthly samples test positive for the presence of total coliform.

Distribution System		Positive for	Positive for
Year	Number Sampled	Total Coliform	E.Coli
2016	974	0	0
2015	989	3	0*
2014	987	4	1
2013	981	1	0
2012	995	2	0

\*In March 2015 Fecal Coliform was no longer tested due to regulation changes

### Additional Bacteriological Samples Analyzed for the Village of Skokie

Year	Number Sampled
2016	889
2015	887
2014	892
2013	899
2012	914

Raw Water	Year	Number Sampled	Colony Count	
			Average	Maximum
	2016	732 (Twice Daily)		
	2015	730 (Twice Daily)	59	>200
	2014	728 (Twice Daily)	38	>200
	2013	730 (Twice Daily)	45	>200
	2012	732 (Twice Daily)	41	>200

After Primary Treatment	Year	Number Sampled	Colony Count	
			Average	Maximum
	2016	732 (Twice Daily)	0	0
	2015	730 (Twice Daily)	0	0
	2014	729 (Twice Daily)	0	0
	2013	730 (Twice Daily)	0	0
	2012	732 (Twice Daily)	0	0

Plant Tap A.M. and P.M. Samples	Year	Number Sampled	Colony Count	
			Average	Maximum
	2016	1403 (4 times Daily)	0	0
	2015	1460 (4 times Daily)	0	0
	2014	1459 (4 times Daily)	0	0
	2013	1460 (4 times Daily)	0	0
	2012	1464 (4 times Daily)	0	0

## Taste & Odor, Turbidity, Temperature and Fluoride Report of Evanston Water Quality Control Laboratory

### Taste & Odor

Year	Number of Tests
2016	503
2015	506
2014	498
2013	508
2012	504

### Turbidity (Expressed in Nephelometric Turbidity Units or NTU)

EPA standard is <0.3 NTU in 95% of samples and never >1 NTU in any single sample of finished water.

Year	Raw Water			After Primary Treatment			Plant Tap		
	Avg	Max	Min	Avg	Max	Min	Avg	Max	Min
2016	7.26	60	0.32	0.63	7.7	0.11	0.08	0.61	0.07
2015	6.49	79.70	0.42	0.61	1.81	0.23	0.08	0.19	0.06
2014	4.11	61.4	0.17	0.66	2.20	0.21	0.08	0.24	0.07
2013	8.49	85.5	0.49	0.75	2.35	0.06	0.08	0.16	0.07
2012	9.59	124.0	0.55	0.74	2.71	0.25	0.08	0.18	0.06

### Raw Water Temperature

Year	Average	Maximum	Minimum
2016	11.1°C / 52.0°F	24.6°C / 76.3°F	1.0°C / 33.8°F
2015	10.2°C / 50.4°F	22.5°C / 72.5°F	0.9°C / 33.6°F
2014	10.0°C / 50.0°F	23.8°C / 74.8°F	0.8°C / 33.4°F
2013	11.2°C / 52.1°F	24.5°C / 76.1°F	0.8°C / 33.4°F
2012	12.9°C / 55.3°F	26.8°C / 80.2°F	2.1°C / 35.8°F

### Fluoride Content (EPA target is 0.7 ppm)

Year	Plant Tap			Distribution		
	Avg	Max	Min	Avg	Max	Min
2016	0.70	0.85	0.16	0.71	0.82	0.64
2015	0.94	1.11	0.21	0.98	1.18	0.75
2014	0.96	1.10	0.22	1.07	1.07	0.90
2013	0.97	1.11	0.90	0.98	1.09	0.90
2012	0.98	1.09	0.90	0.98	1.08	0.90

## Chlorine Residual (ppm)

### Report of Evanston Water Quality Control Laboratory

#### Filter Influent

Year	Free Residual			Total Residual		
	Avg	Max	Min	Avg	Max	Min
2016	0.70	1.02	0.50	0.84	1.19	0.63
2015	0.68	1.06	0.46	0.81	1.21	0.11
2014	0.68	1.14	0.42	0.81	1.29	0.52
2013	0.64	0.92	0.35	0.77	1.06	0.49
2012	0.68	1.04	0.44	0.81	1.19	0.54

#### Filter Effluent

Year	Free Residual			Total Residual		
	Avg	Max	Min	Avg	Max	Min
2016	0.62	0.92	0.40	0.75	1.10	0.50
2015	0.59	0.92	0.39	0.93	76	0.49
2014	0.60	1.04	0.38	0.72	1.19	0.51
2013	0.55	0.83	0.30	0.67	0.97	0.40
2012	0.59	0.92	0.40	0.71	1.04	0.51

#### Plant Tap

Year	Free Residual			Total Residual		
	Avg	Max	Min	Avg	Max	Min
2016	0.72	0.92	0.54	0.87	1.12	0.69
2015	0.69	0.93	0.5	0.84	1.13	0.62
2014	0.68	1.00	0.51	0.83	1.20	0.61
2013	0.66	0.88	0.46	0.80	1.07	0.60
2012	0.67	1.00	0.48	0.81	1.15	0.60

#### Distribution Tap

Year	Free Residual			Total Residual		
	Avg	Max	Min	Avg	Max	Min
2016	0.45	0.73	0.17	0.61	0.94	0.34
2015	0.44	0.78	0.17	0.60	0.92	0.30
2014	0.45	0.80	0.17	0.61	1.02	0.31
2013	0.45	0.78	0.18	0.61	0.99	0.34
2012	0.44	0.90	0.13	0.59	1.05	0.30

## Phosphate, pH, Alkalinity and Hardness

### Report of Evanston Water Quality Control Laboratory

#### Phosphate (EPA standard is 0.15 - 0.50 ppm)

Year	Number of Tests	Plant Tap		
		Avg	Max	Min
2016	365	0.28	0.41	0.17
2015	365	0.25	0.35	0.18
2014	365	0.24	0.30	0.20
2013	365	0.21	0.24	0.18
2012	365	0.16	0.26	0.16

#### pH (EPA standard is 7.1 - 7.9)

Year	Number of Tests	Raw Water			Plant Tap		
		Avg	Max	Min	Avg	Max	Min
2016	732	8.3	8.6	7.8	7.6	7.8	7.2
2015	730	8.3	8.5	7.9	7.6	7.8	7.3
2014	729	8.3	8.6	8.0	7.6	7.7	7.3
2013	730	8.3	8.5	8.0	7.6	7.9	7.3
2012	732	8.3	8.5	8.1	7.6	7.9	7.6

#### Alkalinity (ppm)

Year	Number of Tests	Raw Water			Plant Tap		
		Avg	Max	Min	Avg	Max	Min
2016	732	106	114	93	99	110	84
2015	730	106	121	92	100	115	91
2014	730	109	134	92	102	130	91
2013	730	105	112	94	98	108	90
2012	732	105	112	92	98	108	84

#### Hardness (ppm as CaCO<sub>3</sub>)

Year	Number of Tests	Raw Water			Finished Water		
		Avg	Max	Min	Avg	Max	Min
2016	732	136	149	119	134	154	119
2015	730	135	149	124	133	154	124
2014	730	135	149	104	133	149	97
2013	730	135	142	111	131	141	119
2012	732	136	149	124	132	149	134

## Detected Substances: 2016 Water Quality Data

<b>Substance</b>	<b>MCLG</b>	<b>Highest Allowed (MCL)</b>	<b>Highest Level Detected</b>	<b>Range of Levels Detected</b>	<b>Violation</b>	<b>Source of Contamination</b>
Turbidity (NTU) (Cloudiness)	NA	TT=Monitored by % exceeding 0.3 NTU and max allowed is 1 NTU	100% of samples meet 0.3 NTU; 0.19 NTU Highest single measurement	0.06 - 0.61	NO	Soil runoff
Fluoride (ppm)	4	4	0.7	Single Sample	NO	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen](ppm)	10	10	0.6	Single Sample	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Sodium (ppm)	NA	NA	7.7	Single Sample	NO	Erosion from naturally occurring deposits
Barium (ppm)	2	2	0.02	Single Sample	NO	Discharge of drilling wastes; Discharge from metal refineries; Erosion of Natural deposits
Combined Radium 226/228 (pCi/L)b	0	5	0.99	Single Sample	NO	Erosion of natural deposits
Gross Alpha excluding Radon and Uranium (pCi/L)b	0	15	0.16	Single Sample	NO	Erosion of natural deposits
Cotinine (ppb)	NOT REGULATED	NOT REGULATED	0.001	Single Sample	NO	Nicotine metabolite/waste water discharge
Tris(chloropropyl) phosphate (ppb)	NOT REGULATED	NOT REGULATED	0.01	Single Sample	NO	Flame retardant
Acesulfame-K (ppb)	NOT REGULATED	NOT REGULATED	0.12	Single Sample	NO	Artificial sweetener
Sucralose (ppb)	NOT REGULATED	NOT REGULATED	0.039	Single Sample	NO	
Sulfate (ppm)	NOT REGULATED	USEPA National Secondary Standard of 250	24	Single Sample	NO	Naturally occurring, coagulant residual

## Detected Substances: 2016 Water Quality Data

<i>Disinfectants and Disinfection By-Products</i>	<i>MCLG</i>	<i>Highest Allowed (MCL)</i>	<i>Highest Level Detected</i>	<i>Range of Levels Detected</i>	<i>Violation</i>	<i>Source of Contamination</i>
Total Trihalomethanes (ppb)	NA	80	25	12.5-37.6	NO	By-product of drinking water chlorination
Total Haloacetic Acids (ppb)	NA	60	9	3.0-10.7	NO	By-product of drinking water chlorination
Chlorine (ppm)	4 MRLDG	4 MRDL	0.4	0.4 - 0.5	NO	Water additive used to control microbes

<i>Lead &amp; Copper</i>	<i>MCLG</i>	<i>Action Level (AL)</i>	<i>90th Percentile</i>	<i>Range of Levels Detected</i>	<i>Violation</i>	<i>Source of Contamination</i>
Lead (ppb)	0	15	3.9	<1 - 11	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.14	<0.001 - 0.510	NO	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems

### Additional Information About Your Water

<i>Measured Parameter</i>	<i>Evanston Minimum</i>	<i>Evanston Maximum</i>	<i>Measured Parameter</i>	<i>Evanston Result</i>
pH (0-14 pH units)	7.2	7.8	Calcium (ppm)	32
Hardness (as mg CaCO <sub>3</sub> /L)	119	154	Chloride (ppm)	14
Hardness (gpg)	7	9	Dissolved Solids (ppm)	150
Alkalinity (ppm)	84	110	Magnesium (ppm)	11
Raw Water Temperature °F	34	76	Potassium (ppm)	1.4

# Non-Detected Contaminants

## 2016 Water Quality Data

Inorganic Contaminants	MCLG	MCL	EEA MRL	Level Found
ARSENIC (ppb)	none	50	1	ND
CADMIUM (ppb)	5	5	1	ND
CHROMIUM (ppb)	200	200	0.01	ND
CYANIDE (ppb)	n/a	1000	0.02	ND
IRON (ppb)	n/a	150	2	ND
MANGANESE (ppb)	2	2	0.1	ND
MERCURY (INORGANIC) (ppb)	n/a	100	1	ND
NICKEL	50	50	2	ND
SELENIUM (ppb)	6	6	1	ND
ANTIMONY (ppb)	4	4	0.3	ND
BERYLLIUM (ppb)	0.5	2	0.3	ND
THALLIUM (ppb)	n/a	5000	5	ND
ZINC (ppb)	n/a	5000	5	ND
NITRITE (AS NITROGEN) (ppm)	1	1	0.01	ND

### Synthetic Organic Contaminants

ENDRIN (ppb)	2	2	0.1	ND
BHC- GAMMA (LINDANE)	200	200	0.1	ND
METHOXYCHLOR (ppb)	40	40	0.1	ND
TOXAPHENE (ppb)	0	3	1	ND
DIQUAT (ppb)	20	20	2	ND
DALAPON (ppb)	200	200	5	ND
ENDOTHALL (ppb)	100	100	9	ND
DI(2-ETHYLHEXYL)ADIPATE (ppb)	400	400	0.6	ND
OXAMYL (VYDATE) (ppb)	200	200	2	ND
SIMAZINE (ppb)	4	4	0.35	ND
DI(2-ETHYLHEXYL)PHTHALATE (ppb)	0	6	0.6	ND
PICHLORAM (ppb)	500	500	0.4	ND
DINOSEB (ppb)	7	7	1	ND
HEXACHLOROCYCLOPENTADIENE (ppb)	50	50	0.5	ND
ALDICARB SULFOXIDE	n/a	n/a	1	ND
ALDICARB SULFONE	n/a	n/a	1	ND
CARBOFURAN (ppb)	40	40	0.9	ND
ALDICARB	n/a	n/a	1	ND
ATRAZINE (ppb)	3	3	0.3	ND
ALACHLOR (LASSO)(ppb)	0	2	0.2	ND
HEPTACHLOR	0	100	0.04	ND
HEPTACHLOR EPOXIDE (ppt)	0	100	0.02	ND
DIELDRIN	n/a	1	0.05	ND
2,4-Dichloro-Phenoxyacetic Acid (2,4-D) (ppb)	10	10	1	ND
2,4,5-TP (SILVEX) (ppb)	50	50	1	ND
HEXACHLOROBENZENE (ppb)	0	1	0.1	ND
BENZO (A) PYRENE (ppb)	0	200	0.1	ND
PENTACHLOROPHENOL (PCP) (ppb)	0	1	0.4	ND
ALDRIN (ppb)	n/a	1	0.05	ND
POLYCHLORINATED BIPHENYLS (PCB) (ppb)	0	500	varies	ND
TOTAL DDT (ppb)	n/a	50*	1	ND
1,2 DIBROMO3-CHLOROPROPANE (DBCP) (ppb)	0	0.2	0.02	ND
ETHYLENE DIBROMIDE (EDB) (ppb)	0	50	0.01	ND
CHLORDANE (ppb)	0	2	0.2	ND

## Non-Detected Contaminants

### 2016 Water Quality Data

THM/HAA5	MCLG	MCL	EEA MRL	Level Found
MONOCHLOROACETIC ACID (ppb)	70	na	2	ND
MONOBROMOACETIC ACID (ppb)	na	na	1.0	ND

Unregulated Contaminants	MCLG	MCL	EEA MRL	Level Found
Bisphenol A (ppb)	na	na	0.1	ND
Nonylphenol, isomer mix (ppb)	na	na	0.5	ND
4-n-Octylphenol (ppb)	na	na	0.5	ND
4-tert-Octylphenol (ppb)	na	na	0.5	ND
Pentachlorophenol (ppb)	na	na	0.1	ND
Phenylphenol (ppb)	na	na	0.1	ND
Tetrabromobisphenol A (ppb)	na	na	0.1	ND
2,4,6-Trichlorophenol (ppb)	na	na	0.1	ND
Pharmaceutically Active Compounds Positive	na	na	varies	ND
Pharmaceutically Active Compounds Negative	na	na	varies	ND

MCL= Maximum Contaminant Level

MCLG = Maximum Contaminant Level Goal

EEA MRL= Eurofins Eaton Analytical Minimum Reporting Level

ND = Not Detected

## **Lead and Copper Statement**

### **Report of Water Quality Control Laboratory**

There is no detectable lead in the water produced by the City of Evanston's water treatment plant. Lead enters the water from lead solder and/or lead pipes in water services, or through plumbing fixtures. To minimize contamination resulting from corrosion, the EPA established a lead action level of 15 parts per billion (ppb) in 1992. The 90<sup>th</sup> percentile result of samples analyzed for lead and copper content in homes with lead pipes must be less than the action levels of 15 ppb and 1.3 ppm, respectively.

Lead and copper sampling is performed every three years in compliance with state law. In 2014, Evanston sampled water from 30 homes with lead service lines and analyzed them for lead and copper content. All results were below the action levels. The 90<sup>th</sup> percentile level for lead in these samples was 3.9 ppb. The 90th percentile level for copper was 0.14 ppm.

## Definitions and General Explanations

**Action Level** – The concentration of a contaminant, which, if exceeded, triggers treatment or other required actions by the water supply.

**Disinfection By-Products** – Total Trihalomethanes and Total Haloacetic Acids are used to regulate the amount of allowable by-products of chlorination.

**EPA** – Environmental Protection Agency

**Fluoride** – The Illinois Department of Public Health recommends a target of 0.7 ppm.

**Lead and Copper** – There is no detectable lead in the water provided to the Evanston community. Lead enters the water from lead solder, lead pipes, or plumbing fixtures. To minimize contamination resulting from corrosion, the EPA established a lead action level of 15 parts per billion (ppb) in 1992. The 90<sup>th</sup> percentile result of samples analyzed for lead and copper content in homes with lead pipes must be less than the action level of 15 ppb and 1.3 ppm respectively.

**MCL** – Maximum Contaminant Level, the highest level of a contaminant that is allowed in drinking water. A MCL is set as close to a MCLG as feasible using the best available treatment technology.

**MCLG** – Maximum Contaminant Level Goal, the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**mg CaCO<sub>3</sub>/L** – milligrams of calcium carbonate per liter.

**mrem/yr** – Millirems Per Year. A measure of radiation absorbed by the body.

**MRDL** – Maximum Residual Disinfection Level. The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**MRDLG** – Maximum Residual Disinfection Level Goal. The level of disinfectant in drinking water below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

**NA** – Not applicable.

**NTU** – Nephelometric Turbidity Units. A measure of the cloudiness of water.

**pCi/L** – Picocuries per liter. A measure of radioactivity.

**ppm** – Parts per million. A measure of the concentration of a substance in water. An equivalent unit of measurement is milligrams per liter (mg/L).

**ppb** – Parts per billion. A measure of the concentration of a substance in water. An equivalent unit of measurement is micrograms per liter (µg/L).

**Sodium** – There is not a state or federal MCL for sodium. Sodium levels below 20 mg/L (ppm) are not considered to be a public health issue.

**TT** – Treatment Technique. A required process to reduce the level of a contaminant.

**Turbidity** – A measurement of the cloudiness of the water caused by suspended particles. This is monitored because it is a good indicator of water quality as well as the effectiveness of the filtration and disinfection processes.

**TOC** – Total Organic Carbon. The Evanston Water Supply monitored the percentage of TOC removal quarterly and met all TOC removal requirements set by the EPA.

# Distribution

The Distribution Division manages operation, maintenance, and repair of Evanston's water mains, valves, fire hydrants, and the City's portion of water service lines. This includes repairing water main breaks and water service leaks; and installing new valves, hydrants, and water mains to improve the operation and efficiency of Evanston's water distribution system. Annual maintenance programs administered by this division include water main leak surveying, valve exercising, and fire hydrant testing. The Distribution Division also performs routine water quality sampling in buildings throughout Evanston, and administers the City's cross connection control program. These two programs ensure that water remains safe to drink after leaving the water treatment plant.

Evanston has had a water distribution system since the 1870s, longer than most communities in the Chicago area. The original water mains were made of wood, with a transition to cast iron water mains by the 1890s. After completion of the water treatment plant in 1914, the plentiful supply of safe drinking water drew many new residents and businesses to Evanston. The distribution system underwent significant expansion over the next few years, and many of those 90 to 100+ year-old water mains are still in operation today. Evanston manages an annual water main renewal program to replace and rehabilitate old water mains as they develop maintenance problems.



A Distribution Division field crew installing a new fire hydrant connection on a 24" diameter water main, to improve the City's ability to clean and test this main.





Pieces of wood water main from Evanston's original water distribution system.

# Fire Hydrants

## System Data and Maintenance\*

Fire Flow Testing	2012	2013	2014**	2015	2016
Fire Department	1,400	1,417	1,100	1,477	1,428
Public Works Agency	42	22	0	0	13

Installation & Maintenance	2012	2013	2014	2015	2016
Installed (new)	10	18	12	11	18
Replaced	17	22	15	13	18
Repaired	73	175	315	51	327



\* All work completed by Public Works Agency staff unless otherwise noted.

\*\* Testing was limited to avoid impacting water pressure during transmission main improvements.

\*\*\* Changes due to hydrant removal/addition during water main improvements and utility atlas updates.


## Water Distribution System Valves

### System Data and Maintenance\*

Testing & Inspection	2012	2013	2014	2015	2016
In-House	1,071	1,117	910	908	828
Contractor	0	0	0	0	0

Installation & Maintenance	2012	2013	2014	2015	2016
Installed (new)	11	14	14	13	27
Replaced	26	44	34	16	37
Repaired	38	41	19	55	19

Number of Valves by Size	2012	2013	2014	2015	2016
4" or smaller	30	28	23	23	23
6"	1011	996	979	975	961
8"	484	492	507	513	521
10"	185	183	189	192	199
12"	235	243	243	244	252
14"	2	2	2	2	2
16"	49	46	50	50	50
18"	4	4	5	5	5
20"	2	2	2	2	2
24"	30	33	33	33	33
30"	11	12	12	12	13
36"	12	12	12	12	13
42"	2	2	2	2	2
48"	2	2	2	2	2
<b>Total</b>	<b>2,059</b>	<b>2,057</b>	<b>2,061</b>	<b>2,067</b>	<b>2,078</b>



\* All work completed by Public Works Agency staff unless otherwise noted.

\*\* Valves are buried beneath paved surfaces and are not accessible for field verification of age.


## Water Mains

### System Data and Maintenance\*

Improvements (lineal feet)	2012	2013	2014	2015	2016
Replaced by City	181	50	0	0	0
Replaced by Contractor	9,868	8,870	8,526	4,303	8,172
Rehabilitated by Contractor	0	0	569	395	3,802

Water Main Break Repairs	2012	2013	2014	2015	2016
Blow-Out	56	21	32	5	21
Shear Break	8	30	36	18	7
Damage	2	3	2	0	0
Total	66	54	70	23	28

Pipe Sizes (length in miles)**	2012	2013	2014	2015	2016
4" or smaller	1.83	1.67	1.37	1.37	1.37
6"	76.02	74.99	72.99	73.26	71.88
8"	27.62	28.35	28.81	28.93	29.01
10"	12.47	12.30	12.76	12.81	13.18
12"	17.42	17.73	17.51	17.66	17.95
14"	0.37	0.37	0.37	0.37	0.37
16"	6.51	6.25	6.26	6.26	6.26
18"	0.83	0.83	0.83	0.83	0.83
20"	0.56	0.56	0.56	0.56	0.56
24"	8.30	8.60	8.60	8.60	8.60
30"	1.69	1.69	1.69	1.69	1.69
36"	3.30	3.30	3.30	3.30	3.30
42"	0.04	0.04	0.04	0.04	0.04
48"	0.68	0.68	0.68	0.68	0.68
Total	157.63	157.35	155.77	156.36	155.72



\* All work completed by Public Works Agency staff unless otherwise noted.

\*\* Changes due to water main removal/addition during improvement projects and utility atlas updates.

## Water Services


### System Data and Maintenance\*

**Water Service Accounts: 15,129** (metered domestic services + unmetered fire services)

Installation & Maintenance	2012	2013	2014	2015	2016
New Services Installed	4	2	19	13	3
Service Taps Replaced***	55	28	33	36	53
Services Replaced by Contractor	-	188	124	147	78
Service Leaks Repaired	14	34	36	22	21

### Breakdown of In-House Maintenance Costs

	2012	2013	2014	2015	2016
Water Mains	\$274,946	\$213,075	\$322,859	\$83,864	\$109,939
Fire Hydrants	\$95,065	\$109,048	\$42,398	\$65,197	\$41,150
Water Services	\$135,193	\$159,592	\$293,347	\$166,275	\$133,658
Valves	\$102,763	\$128,645	\$43,665	\$148,309	\$65,263
Snow & Ice Removal	\$24,085	\$42,384	\$74,519	\$46,314	\$38,105
Assist Contractor	\$70,848	\$69,516	\$71,591	\$57,511	\$96,170
JULIE Locates	\$62,845	\$73,519	\$71,911	\$108,200	\$117,375
Equip/Facility Maint.	\$62,757	\$85,631	\$62,051	\$77,189	\$86,794
Assist Other City Depts.	\$16,053	\$11,364	\$25,509	\$8,878	\$26,713
Assist W&S Divisions	\$13,739	\$10,811	\$5,581	\$20,610	\$4,617
Safety & Training	\$10,853	\$18,883	\$17,207	\$22,639	\$31,543
Misc.	\$25,370	\$45,422	\$88,294	\$48,069	\$60,838
<b>Total</b>	<b>\$951,150</b>	<b>\$894,518</b>	<b>\$967,890</b>	<b>\$1,118,932</b>	<b>\$812,166</b>



\* All work completed by Public Works Agency staff unless otherwise noted.


\*\* Includes metered domestic water service accounts and unmetered fire service accounts.

\*\*\* Differentiation of replacement of existing water services from new water service installations began in 2012.

# Water Main Improvements

The Public Works Agency manages an annual water main improvement program, with the goal of renewing at least 1.5 miles of water mains annually (1% annual system-wide renewal rate). This program addresses water mains that have developed maintenance problems due to their age, as well as water mains that need to be enlarged to satisfy current fire flow requirements.


## Water Mains Installed or Rehabilitated



## Leak Detection Program

In 2013, the Public Works Agency developed a City-wide surveying program to catch water main leaks early and minimize our water loss. This saves operating costs to produce the water, conserves a vital natural resource, and allows more water mains to be repaired proactively rather than on an emergency basis.

The Public Works Agency uses leak noise loggers, small transmitters that sense the sound waves created by water escaping through a hole in a water main, to test water mains for leaks throughout the year. This proactive leak surveying program began in 2013, and water distribution crews were able to survey all 157 miles of Evanston's water mains in 2013-2014.



The 2015 survey found three leaks on building water service pipes and two breaks on water mains. These defects were all successfully repaired, and the estimated water savings is over 9.90 Million Gallons (MG) per year.

Year	Miles of Water Main Surveyed	Water Service Leaks Found	Water Main Breaks Found	Water Savings After Repairs
2013	59	1	2	8.85 MG/year
2014	98	4	1	6.26 MG/year
2015	135	3	2	9.90 MG/Year
2016	149	2	3	13.534 MG/Year
<b>Totals</b>	<b>441</b>	<b>10</b>	<b>8</b>	<b>38.544 MG/year</b>

In 2017 and future years, the Public Works Agency anticipates being able to survey the entire 157 miles of water mains in Evanston every year. This frequency is important since water main breaks and leaks can develop at any time; a water main that shows no signs of leakage one year can develop a large leak by the next year.


## Cross Connection Control

A cross connection is a point in a plumbing system where the potable (safe, drinkable) water supply is connected to a non-potable (polluted or untreated) source. A cross connection exists whenever the drinking water system is or could be connected to any non-potable source. If cross connections are not properly protected and there is a drop in pressure, untreated sources and dirt can be pulled into household plumbing systems.

The State of Illinois and the City of Evanston require mandatory backflow protection on certain households and facilities where high health-hazard-type cross connections are normally found. Underground lawn sprinkling systems, fire protection systems, hospitals and health clinics, mortuaries, laboratories, food and beverage processing and car washes are just a few of the locations where backflow prevention is necessary to protect the quality of our public water supply.

In 2008, the Public Works Agency hired a plumbing inspector to manage the City's cross connection control program. Since that time, over 4,000 backflow prevention devices have been added to the City's inventory and are now regularly inspected for compliance with State and City codes. An annual tracking system enables the City to ensure these devices are properly maintained throughout their life cycle. This helps keep the high quality drinking water produced by the City's water treatment plant safe to drink after entering the water distribution system.

Year	Backflow Prevention Devices Certified Annually
2012	2,786
2013	3,356
2014	3,644
2015	4,039
2016	4,241



# Metering

The Meter Division manages water meter reading and billing for Evanston's 14,537 retail water and sewer customers, working with the City's Collector's Office to process water/sewer bill payments and cross connection control fees. The Meter Division also coordinates with the Distribution Division to manage replacement of damaged and obsolete water meters, accuracy testing for large water meters, and water service shutoff and restoration. In 2013-2014, the Meter Division managed Evanston's migration to a new Advanced Metering Infrastructure (AMI) system, which has improved accuracy and efficiency of the water metering and billing processes. The AMI system also generates automated hourly meter reads and leak alerts for customers to help reduce water loss.

Evanston has been metering water consumption since at least the early 1920s, well before many communities in the Chicago area. Water rates established to pay for the 1914 water treatment plant were only \$0.16 per 1,000 gallons of metered water use! The City originally sent meter reading staff into every building in the City once a quarter to manually read water meters. Water metering technology has evolved considerably over the last 100 years. Current technology allows meter readings to be taken automatically every hour, with once-daily, wireless upload of readings to a computerized billing system.




A Public Works Agency employee installs a new remote water meter reading unit on the exterior of a home as part of the Advanced Metering Infrastructure (AMI) project.

This unit makes it possible for meter readings to be transmitted via wireless network without City staff having to visit each property to manually read the meters.



Evanston's first female water meter readers, Dorothy Jay (left) and Marjorie Nantkes (right). They were hired in 1943 to replace men serving in World War II.


## Automatic Metering Infrastructure (AMI) System



### How it works:

- A Meter Information Unit (MIU) is attached to every water meter in Evanston. The MIU takes a meter reading once an hour and stores these readings for a full day. Each MIU broadcasts the readings once a day using a wireless transmitter.
- The Data Collector Unit (DCU) receives the meter readings from the MIUs. Evanston currently has 6 DCUs located on various buildings throughout the community. Each DCU sends its meter reading information to the Network Control System at the Water Treatment Plant on a daily basis.
- The Network Control System supports customer service and system management activities. It transfers the meter readings to the billing system to generate bi-monthly water and sewer bills for Evanston customers.
- The Network Control System monitors fluctuations in water usage, and sends leak alerts to the network administrator if a customer's real-time meter readings are significantly higher than historical usage trends.
- The AMI system includes an online portal where Evanston customers can monitor their water usage, compare usage trends under various weather conditions, and set up leak alerts of their own.

# Transmitter Tower Locations



## Water Meter Inventory

Water is billed bi-monthly in units of 100 cubic feet (CCF). The minimum service charge every two months is based on water meter size as follows:

Meter Size	Number of Meters
5/8"	11660
3/4"	991
1"	1095
1.5"	260
2"	473
3"	55
4"	26
6"	3
8"	4
Total	14537

## Water Rates for Evanston Customers

Water is billed bi-monthly in units of 100 cubic feet (CCF). The minimum service charge every two months is based on water meter size as follows:

Meter Size	Minimum Charge Effective 1/1/2016
5/8" & 3/4"	\$7.78
1"	\$15.53
1 1/2"	\$29.07
2"	\$45.77
3"	\$80.61
4"	\$129.13
6"	\$227.72
8"	\$385.46

The minimum demand charge includes the first five hundred cubic feet (500 CCF) of water consumed every two months, which is roughly equivalent to 3,740 gallons of water.




Water usage over the minimum is billed at \$2.18 per CCF effective 1/1/2016. This is equivalent to a rate of \$2.91 per 1,000 gallons.

# Water Customer Classes and Metered Usage

## Billed by Category and Water Usage for 2016

Category	Number of Accounts	2016 Usage (CCF)*
<b>Metered Water Services</b>		
Single-Family	10,008	916,853
Multi-Family	3,412	1,140,860
Commercial	945	1,061,080
Industry	30	9,808
City	31	14,351
Park	77	5,969
School	34	37,645
<b>Subtotal</b>	<b>14,537</b>	<b>3,186,566</b>
<b>Unmetered Water Services</b>		
Fire Services**	592	-
<b>Totals</b>	<b>15,129</b>	<b>3,186,566</b>


### Water Service Accounts by Category:



\* Water usage is metered in units of 100 cubic feet (CCF). 100 CCF is approximately 748 gallons

\*\* Fire services are not metered. They are billed a flat charge twice per year.

## Water Usage Breakdown for Evanston Customers



# Sewer

The Sewer Division manages the operation, inspection, maintenance, and repair of the City's sewer mains and structures (sewer manholes, catch basins, and stormwater inlets). This includes proactive programs such as sewer main and drainage structure cleaning, root cutting, and televised internal sewer main inspection; as well as responding to all reports of sewer backups and flooding. This division also inspects work done by contractors including sewer main lining and manhole rehabilitation. Sewer Division staff conduct regular inspection of sewer outfalls and other facilities throughout Evanston for compliance with the City's sewer system operating permits with the Illinois Environmental Protection Agency.

Much of Evanston's sewer system was constructed in the late 1800s to early 1900s. These pipes are far too small to convey both domestic sewage and stormwater runoff as they were intended to do. Beginning in the early 1990s, Evanston constructed a network of relief sewers, which are much larger and deeper than the original combined sewers. The relief sewers now convey most of the stormwater runoff, to avoid overwhelming the combined sewers during rain events. The relief sewers run to a number of drop shafts located along the North Shore Channel, where they discharge directly to the Metropolitan Water Reclamation District's (MWRD) deep tunnel system.




Sewer Division staff operate a sewer cleaning truck to remove debris from a catch basin.



This drop shaft was one of the starting points for a tunneling machine that installed Evanston's relief sewers as a part of the Long Range Sewer Program in 1992 – 2008. Relief sewers are installed at depths of up to 60 feet to efficiently collect and transport large volumes of stormwater without impacting customers and other utilities.

## Sewer Revenues\*

	2015	2016
Operations	\$12,276,650	\$12,100,000
Debt Proceeds	\$0	\$0
Investment Earnings	\$1,000	\$4,450
Miscellaneous**	\$4,165	\$21,600
<b>Total Sewer Revenue</b>	<b>\$12,281,815</b>	<b>\$12,126,050</b>




\* Financial data are based on actual expenses and do not include audit adjustments such as depreciation and inventory. For audited financial records, see the Comprehensive Annual Financial Report for the City of Evanston, <http://www.cityofevanston.org/transparency/budget-financial-reports/>.

\*\* Miscellaneous Revenue includes fees, grants, and merchandise sales.

## Sewer Operating & Maintenance Expenses\*

	2015	2016
Sewer Operations	\$1,802,652	\$1,698,475
Other Oper. Expenses	\$6,611	\$8,500
Interfund Transfers	\$818,608	\$987,194
Capital Outlay	\$581,270	\$2,195,200
Annual Rehab Programs**	\$1,002,000	\$706,603
Debt Service	\$9,613,727	\$9,222,913
<b>Total</b>	<b>\$13,824,868</b>	<b>\$14,818,885</b>




\* Financial data are based on actual expenses and do not include audit adjustments such as depreciation and inventory. For audited financial records, see the Comprehensive Annual Financial Report for the City of Evanston, <http://www.cityofevanston.org/transparency/budget-financial-reports/>.

\*\*Includes CIPP sewer rehabilitation, drainage structure replacement, stormwater management improvements, and emergency sewer repairs


# Major Combined Sewer System

The combined sewer system is Evanston's original sewage collection system. Much of this system was constructed in the late 1800s to early 1900s. The system was intended to capture and convey both domestic sewage and stormwater runoff, though as early as the early 1900s the City experienced flooding and basement backups during rain storms because the combined sewer pipes were not large enough to handle stormwater. In the early 1990s, Evanston began constructing a relief sewer system to convey the majority of the stormwater runoff and lessen the risk of basement backups.




# Major Relief Sewer System

Starting as long ago as 1902, property owners in Evanston experienced sewage backing up into basements during significant rain events. In 1990, the City Council approved a Long Range Sewer Improvement Program to mitigate property damage caused by basement backups. As part of this program, a network of large diameter relief sewers was constructed between 1991 – 2008 at a cost of \$210 million. These pipes are larger and deeper than the combined sewers, and convey stormwater runoff and sewage overflows to avoid overwhelming the combined sewers.



# Major Storm Sewer System

The storm sewer system discharges directly to the North Shore Channel and Lake Michigan. It is only utilized during rain events to convey stormwater from the streets to the channel or the lake. Most of the storm sewers in southwest Evanston were installed in the late 1970s to early 1980s. The remainder of storm sewers in this area, as well as the storm sewers in north central and northeast Evanston, were installed between 1991-2008 as part of the Long Range Sewer Improvement Program. Evanston operates the storm sewer system under a special permit issued by the Illinois Environmental Protection Agency.




## Sewer Mains

### System Data and Maintenance\*

Sewer Length by Type	Pipe Length (miles)				
	2012	2013	2014	2015	2016
Combined Sewer	143.78	143.93	143.85	144.30	144.27
Relief Sewer	51.78	52.65	52.82	53.54	53.69
Storm Sewer	16.21	16.31	16.31	16.29	16.30
Total Length	211.77	212.89	212.98	214.13	214.26

Sewer Installation and Maintenance	Pipe Length (feet)				
	2012	2013	2014	2015	2016
Installed (new)	239	1,682	0	2,782	0
Replaced	0	0	0	0	0
CIPP Rehabilitation (Lining)	8,850	15,995	12,059	11,330	7,753
Spot Repair	1,183	4,804	780	2,143	2,943
Clean - Hydroflush	242,791	180,309	136,679	110,419	217,566
Clean - Root Cut	5,372	7,657	14,412	39,987	8,400
Inspection - General	19,695	21,421	26,570	45,777	28,492
Inspection - Televised	83,942	78,022	69,805	50,300	51,602
Inspection - Storm-related**	0	1,981	971	530	0



\* All work performed by the Public Works Agency except CIPP Rehabilitation (Lining).

\*\* Includes sewers installed as part of alley improvement projects.

\*\*\* Inspection of City sewer mains as a result of sewer surcharge during or after a wet weather event, and inspection of storm sewer outfalls into the North Shore Channel.

\*\*\*\* Mains of unknown age were installed prior to detailed record keeping on sewer installations.

## Length of Sewer Mains

### By Type and Diameter

Diameter	Combined Sewer		Relief Sewer		Storm Sewer	
	Feet	Miles	Feet	Miles	Feet	Miles
<6"	2,993	0.57	243	0.05	0	0.00
6"	796	0.15	0	0.00	0	0.00
8"	21,365	4.05	10,961	2.08	1,933	0.37
9"	124,763	23.63	7,510	1.42	1,031	0.20
10"	108,751	20.60	29,467	5.58	10,994	2.08
12"	224,435	42.51	25,409	4.81	9,703	1.84
14"	1,019	0.19	0	0.00	0	0.00
15"	92,566	17.53	5,903	1.12	5,249	0.99
16"	2,085	0.39	6,160	1.17	724	0.14
18"	61,857	11.72	16,581	3.14	7,695	1.46
20"	8,410	1.59	127	0.02	0	0.00
21"	15,052	2.85	2,747	0.52	1,910	0.36
22"	858	0.16	0	0.00	0	0.00
24"	21,405	4.05	46,295	8.77	15,967	3.02
27"	6,434	1.22	6,373	1.21	3,240	0.61
30"	6,973	1.32	19,185	3.63	3,913	0.74
33"	3,771	0.71	1,309	0.25	482	0.09
36"	19,757	3.74	18,386	3.48	6,730	1.27
39"	421	0.08	0	0.00	0	0.00
40"	377	0.07	0	0.00	0	0.00
42"	6,700	1.27	12,282	2.33	3,570	0.68
45"	1,029	0.19	0	0.00	0	0.00
48"	13,108	2.48	22,580	4.28	7,966	1.51
51"	1,104	0.21	0	0.00	0	0.00
54"	1,981	0.38	3,159	0.60	609	0.12
57"	784	0.15	0	0.00	0	0.00
60"	7,206	1.36	4,916	0.93	3,633	0.69
72"	4,077	0.77	11,640	2.20	0	0.00
78"	0	0.00	5,440	1.03	0	0.00
84"	0	0.00	88	0.02	0	0.00
96"	0	0.00	2,366	0.45	0	0.00
108"	0	0.00	5,025	0.95	0	0.00
113"	0	0.00	9,275	1.76	0	0.00
120"	0	0.00	7,340	1.39	0	0.00
Unknown	1,686	0.32	2,722	0.52	691	0.13
<b>Totals</b>	<b>761,761</b>	<b>144.27</b>	<b>283,486</b>	<b>53.69</b>	<b>86,040</b>	<b>16.30</b>

**Total Sewer Main Length: 214.26 miles**

## Sewer Structures

### System Data and Maintenance


<b>Number of Sewer Structures</b>	2012	2013	2014	2015	2016
Manholes	5,532	5,561	5,566	5,582	5,583
Inlets	2,927	2,973	2,974	3,018	3,024
Catch Basins	6,179	6,203	6,208	6,238	6,246
<b>Total</b>	<b>14,638</b>	<b>14,737</b>	<b>14,748</b>	<b>14,838</b>	<b>14,853</b>

<b>Sewer Structure Installation &amp; Maintenance</b>	2012	2013	2014	2015	2016
Installed (new)	2	16	1	41	3
Replaced	39	5	21	18	9
Repair	133	87	55	73	89
Clean	4,109	2,732	3,181	3,262	2,779
Inspect - General	411	327	161	614	156
Inspect - Storm-Related*	479	1001	985	935	689

\* Inspection of City drainage structures as a result of street or alley flooding during or after a wet weather event.

## Breakdown of In-House Maintenance Costs\*

Description	2012	2013	2014	2015	2016
Sewer Mains	\$413,919	\$449,960	\$355,398	\$344,407	\$396,738
Sewer Structures	\$615,415	\$423,665	\$353,667	\$547,051	\$388,196
Equip/Facility Maint.	\$161,460	\$176,489	\$87,884	\$162,452	\$122,994
Assist W&S Divisions	\$45,855	\$48,692	\$73,275	\$80,729	\$52,271
Snow & Ice Removal	\$31,396	\$66,675	\$243,207	\$68,538	\$32,077
Assist Contractors	\$18,240	\$39,542	\$18,681	\$16,637	\$16,955
Assist Other City Depts.	\$57,269	\$13,569	\$35,943	\$17,107	\$61,226
Safety & Training	\$21,321	\$15,233	\$18,759	\$27,486	\$30,844
Miscellaneous	\$5,966	\$6,808	\$13,868	\$10,588	\$14,874
JULIE Locates	\$1,300	\$135	\$553	\$193	\$357
<b>Total</b>	<b>\$1,372,141</b>	<b>\$1,240,768</b>	<b>\$1,201,233</b>	<b>\$1,275,188</b>	<b>\$1,116,533</b>



\* All work completed by Public Works Agency staff unless otherwise noted.

\*\* Costs fluctuate from year to year due to changes in maintenance needs and prioritization of repair projects.

# Sewer Mains Rehabilitated (Lined)

The Public Works Agency manages an annual sewer improvement program, with the goal of rehabilitating at least 1.5 miles of combined sewer mains annually (minimum 1% annual system-wide renewal rate).

