

Results of Water Samples Taken from Drinking Fountains
Fountains listed as n/o are not open

	Park	Lead (parts per billion) First Draw/ 30 second Flush*	Location
1	Ackerman	nd/nd	Central and McDaniel
2	Ackerman	2.6/1.8	Central and McDaniel [Building]
3	Baker	nd/nd	Keeney and Forest
4	Beck	1.4/nd	2420 Wade
5	Bent #1	nd/nd	Central and Hastings Tennis Courts
6	Bent #2	n/o	Central and Hastings Playground
7	Bent Field House Inside	nd/nd	Harrison and Hastings
8	Bent Field House Outside	1.9/1.9	Harrison and Hastings
9	Brummel Richmond	3.5/nd	Brummel and Richmond
10	Burnham Shores	1.2/nd	Lakefront between Dempster and Hamilton [On Beachhouse]
11	Butler	1.2/nd	Hartrey and Foster
12	Cartwright	3.4/nd	Grant and Prospect
13	Clark Square	nd/nd	Kedzie and Sheridan
14	Clark St. Beach House Beachside	nd/nd	1811 Sheridan Rd.
15	Clark St. Beach House Streetside	1.2/nd	1811 Sheridan Rd.
16	Clyde-Brummel	nd/nd	Brummel and Clyde
17	Dawes #1	nd/nd	Church at Lakefront
18	Dawes #2	nd/nd	Greenwood at Lakefront
19	Eggleston	nd/nd	North of McCormick between Bridge and Hartrey
20	Eiden	nd/nd	724 Washington St.

nd= not detected= <1.00 ppb n/o= not open

*First Draw samples were taken after water was allowed to sit in the pipes for approximately 9-16 hours.
 After the First Draw sample was taken the fountain was flushed for 30 seconds and an additional sample was taken.

Results of Water Samples Taken from Drinking Fountains
Fountains listed as n/o are not open

	Park	Lead (parts per billion) First Draw/ 30 second Flush*	Location
21	Ellingwood	nd/nd	Harrison and Pioneer
22	Elliott #1	nd/nd	Greenleaf at Lakeshore on Fieldhouse
23	Elliott #2	nd/nd	Fountain at Lee St. Beach
24	Fireman's	1.9/2.2	Simpson and Maple
25	Fitzsimons	nd/1.1	Lee and Elmwood
26	Fleetwood Jourdain	nd/nd	Foster and Ashland on Building
27	Fountain Square North	nd/nd	Orrington North of Davis
28	Fountain Square South	nd/nd	Orrington South of Davis
29	Garden	nd/nd	Lakefront North of Sheridan Sq.
30	Harbert	1.5/nd	McDaniel North of Main St.
31	Harper	nd/nd	Lake and Sherman
32	Independence	nd/nd	Central and Stewart
33	James Park	nd/nd	Oakton & Hartrey
34	James Park Building	nd/nd	James Park Building
35	James Park North Ball Field	nd/nd	Oakton and Dodge
36	James Park South Ball Field	nd/nd	Oakton and Dodge
37	Ladd Arboretum- Ecology Center	2.1/nd	2024 Bridge St.
38	Larimer	1.3/nd	Crain and Oak
39	Lawson	2.0/1.4	Sheridan and Clinton Pl.
40	Leah Lomar	3.6/nd	Mulford and Wesley

nd= not detected= <1.00 ppb n/o= not open

*First Draw samples were taken after water was allowed to sit in the pipes for approximately 9-16 hours.

After the First Draw sample was taken the fountain was flushed for 30 seconds and an additional sample was taken.

Results of Water Samples Taken from Drinking Fountains
Fountains listed as n/o are not open

	Park	Lead (parts per billion) First Draw/ 30 second Flush*	Location
41	Leahy	nd/nd	Lincoln and Ridge
42	Lighthouse Landing	1.8/nd	2603 Sheridan Road
43	Lovelace	nd/nd	Gross Point and Isabella
44	Mason	1.7/nd	Church and Florence
45	Mason	nd/1.5	Church and Florence [Building]
46	Merrick Rose Garden	2.2/nd	Lake and Oak
47	McCulloch	nd/nd	Jenks and Broadway
48	Penny	nd/nd	Lake and Ashland
49	Perry	1.8/nd	1741 Hovland Ct.
50	Philbrick	2.1/1.5	Gaffield and Sherman
51	Porter	nd/nd	Simpson and Bennett
52	Raymond	nd/nd	Lake and Chicago
53	Robert Crown	nd/nd	Main and Dewey fountain by soccer field
54	Robert Crown #1	nd/nd	Lee and Dodge
55	Robert Crown	nd/nd	Dewey & Lee
56	Smith	1.7/1.2	Ashland and Lyons
57	Snyder	nd/nd	Judson and Kedzie
58	South Boulevard	1.3/nd	Sheridan Square and Sheridan Road
59	Twiggs #1	nd/nd	Payne and Darrow
60	Twiggs #2	1.8/nd	Simpson and Bridge
61	Twiggs @ Skate Park	nd/nd	Skate Park

nd= not detected= <1.00 ppb n/o= not open

*First Draw samples were taken after water was allowed to sit in the pipes for approximately 9-16 hours.

After the First Draw sample was taken the fountain was flushed for 30 seconds and an additional sample was taken.