

Results of Water Samples Taken from Drinking Fountains 2026

Fountains listed as n/o are not open

Park	Lead	(parts per billion)	First Draw/ 30 second Flush*	Location
1	Ackerman	1.3/nd	Central and McDaniel	
2	Ackerman	1.2/nd	Central and McDaniel [Building]	
3	Baker	nd/nd	Keeney and Forest	
4	Beck	n/o	2420 Wade	
5	Bent #1	nd/nd	Central and Hastings Tennis Courts	
6	Bent #2	n/o	Central and Hastings Playground	
7	Bent Field House Inside	nd/nd	Harrison and Hastings	
8	Bent Field House Outside	nd/nd	Harrison and Hastings	
9	Brummel Richmond	2.7/nd	Brummel and Richmond	
10	Burnham Shores	1.1/nd	Lakefront between Dempster and Hamilton	[On Beachhouse]
11	Butler	nd/nd	Hartrey and Foster	
12	Cartwright	nd/nd	Grant and Prospect	
13	Clark Square	nd/nd	Kedzie and Sheridan	
14	Clark St. Beach House Beachside	nd/nd	1811 Sheridan Rd.	
15	Clark St. Beach House Streetside	nd/nd	1811 Sheridan Rd.	
16	Clyde-Brummel	nd/nd	Brummel and Clyde	
17	Dawes #1	nd/nd	Church at Lakefront	
18	Dawes #2	3.6/nd	Greenwood at Lakefront	
19	Ecology Center- Outside	nd/nd	Ecology Center	
20	Eggleston	nd/nd	North of McCormick between Bridge and Hartrey	

nd= not detected= <1.00 ppb n/o= not open

*First Draw samples were taken after water was allowed to sit in the pipes for approximately 9-16 hours. After the First Draw sample was taken the fountain was flushed for 30 seconds and an additional sample was taken.

Park	Lead	(parts per billion)	First Draw/ 30 second Flush*	Location
21	Eiden	nd/nd	724 Washington St.	
22	Ellingwood	nd/nd	Harrison and Pioneer	
23	Elliott #1	nd/nd	Greenleaf at Lakeshore on Fieldhouse	
24	Elliott #2	nd/nd	Fountain at Lee St. Beach	
25	Fireman's	1.7/1.1	Simpson and Maple	
26	Fitzsimons	nd/nd	Lee and Elmwood	
27	Fleetwood Jourdain	nd/nd	Foster and Ashland on Building	
28	Fountain Square North	nd/nd	Orrington North of Davis	
29	Fountain Square South	nd/nd	Orrington South of Davis	
30	Garden	nd/nd	Lakefront North of Sheridan Sq.	
31	Grey	nd/1.8	Main and Maple	
32	Harbert	2.6/nd	McDaniel North of Main St.	
33	Harper	nd/nd	Lake and Sherman	
34	Independence	nd/nd	Central and Stewart	
35	James Park	nd/nd	Oakton & Hartrey	
36	James Park Building	nd/nd	James Park Building	
37	James Park North Ball Field	nd/nd	Oakton and Dodge	
38	James Park South Ball Field	nd/nd	Oakton and Dodge	
39	Ladd Arboretum- Ecology Center	1.1/nd	2024 Bridge St.	
40	Larimer	nd/nd	Crain and Oak	

nd= not detected= <1.00 ppb n/o= not open

*First Draw samples were taken after water was allowed to sit in the pipes for approximately 9-16 hours. After the First Draw sample was taken the fountain was flushed for 30 seconds and an additional sample was taken.

41	Lawson	2.2/1.0	Sheridan and Clinton Pl.
42	Leah Lomar	2.0/nd	Mulford and Wesley
43	Leahy	1.3/2.4	Lincoln and Ridge
44	Lighthouse Landing	nd/nd	2603 Sheridan Road
45	Lovelace	nd/nd	Gross Point and Isabella
46	Lovelace Field House	nd/nd	Gross Point and Isabella- Field House Inside
47	Mason	nd/nd	Church and Florence
48	Mason	nd/nd	Church and Florence [Building]
49	Merrick Rose Garden	1.2/nd	Lake and Oak
50	McCulloch	nd/nd	Jenks and Broadway
51	Penny	nd/nd	Lake and Ashland
52	Perry	3.3/nd	1741 Hovland Ct.
53	Philbrick	2.6/<1.0	Gaffield and Sherman
54	Porter	nd/nd	Simpson and Bennett
55	Raymond	nd/nd	Lake and Chicago
56	Robert Crown	1.3/nd	Main and Dewey fountain by soccer field
57	Robert Crown #1	nd/nd	Lee and Dodge
58	Robert Crown	2.9/nd	Dewey & Lee
59	Smith	1.5/nd	Ashland and Lyons
60	Snyder	2.9/nd	Judson and Kedzie

nd= not detected= <1.00 ppb n/o= not open

*First Draw samples were taken after water was allowed to sit in the pipes for approximately 9-16 hours. After the First Draw sample was taken the fountain was flushed for 30 seconds and an additional sample was taken.

Park	Lead	(parts per billion)	First Draw/ 30 second Flush*	Location
61	South Boulevard	nd/nd		Sheridan Square and Sheridan Road
62	Twiggs #1	nd/nd		Payne and Darrow
63	Twiggs #2	nd/nd		Simpson and Bridge
64	Twiggs @ Skate Park	nd/nd		Skate Park

nd= not detected= <1.00 ppb n/o= not open

*First Draw samples were taken after water was allowed to sit in the pipes for approximately 9-16 hours. After the First Draw sample was taken the fountain was flushed for 30 seconds and an additional sample was taken.