



**Request for Proposal
26-41**

for

Sherman Plaza Parking Garage Fire Alarm Control Panel (FACP) Replacement

ADDENDUM No. 1

October 8, 2026

Any and all changes to the Request for Proposal are valid only if they are included by written addendum to all potential respondents, which will be emailed prior to the proposal due date. Each respondent must acknowledge receipt of any addenda by indicating in its proposal. Each respondent, by acknowledging receipt of addenda, is responsible for the contents of the addenda and any changes to the bid therein. Failure to acknowledge receipt of addenda may cause the submittal to be rejected. If any language or figures contained in this addendum are in conflict with the original document, this addendum shall prevail.

This addendum consists of the following:

1. Addendum No. 1 is attached and consists of a total of two (2) pages including this cover sheet.

Please contact me at 847-866-2910 or jcooper@cityofevanston.org with any further questions or comments.

Sincerely,

Jessica Cooper
Purchasing Specialist

RFP No. 26-41

Sherman Plaza Parking Garage Fire Alarm Control Panel (FACP) Replacement

Addendum No. 1

October 8, 2026

This addendum forms a part of the RFP Documents for RFP # **26-41** and modifies these documents.

This addendum consists of the following:

Questions and Answers:

- 1. QUESTION:** Please clarify whether RFP 26-41 requires replacement of all existing devices, notification appliances, emergency communication devices, elevator interfaces, door-holder interfaces and other field devices as required under RFP 25-32, or whether the intent of RFP 26-41 is primarily replacement of the FACP/transponders, associated modules/interfaces and wiring while retaining compatible existing field devices? If field devices are to be replaced, please provide the current device inventory and locations that were included in RFP 25-32.

ANSWER: The intent of RFP 26-41 is the replacement of the Fire Alarm Control Panel (FACP), transponders, associated modules, and interfaces while retaining compatibility with existing field devices which may include, but are not limited to, notification appliances, emergency communication devices, elevator interfaces, door-holder interfaces and any other field devices currently in use at the Sherman Plaza Parking Garage.

Note: Acknowledgment of this Addendum is required in the Submittal.