


# Know who is responsible

When service damage occurs, it's important to understand who is responsible for the repair. Distinguish between areas owned by ComEd and areas owned by the customer.



Item	Responsibility	Description
1	ComEd	Electrical Service Wire coming from ComEd's system (overhead or underground)
2	Customer	Attachment (the point where ComEd equipment attaches to customer property)
3	Customer	Weather Head and wire drip loop (the weather resistant entry point for customer wires going to the meter box)
4	Customer	Riser/Raceway (the conduit that physically protects wires going to the meter box)
5	Customer	Meter Enclosure/Box (contains and safely secures the electric meter)
6	ComEd	Meter (measures the amount of electricity used by the customer)

## Residential Overhead Services

- ComEd will install an overhead service drop span length consistent with good engineering up to a maximum of 150 feet as part of the standard installation. Charges apply for any additional wire required.
- If a longer length is required to reach the customer's premise, additional equipment such as private property poles or extended service wire may be required. This additional equipment is installed and maintained by the customer.

## Residential Underground Services

- ComEd will install underground cable (service wire) to the closest wall up to a maximum of 100 feet as part of the standard installation. Charges apply for any additional cable required.
- After repair work on underground cables is completed, ComEd will back-fill the trench to the original grade.
- If the customer caused the damage, the customer is responsible for the costs to repair the cable, for reseeding or re-sodding the area, and for replacing any structures, fences, patios associated with the damage.
- If ComEd is responsible for the repair (breakdown in cable, etc), ComEd will reseed or resod the affected lawn or yard area back to its original condition.
- Easements must be kept clear of trees, bushes, structures, fences, patios, etc. The restoration of power and repair of cable can be delayed if ComEd cannot safely access its facilities.